

RECEIVED BY EMAIL

4/14/2023, 2:27 PM

ARIZONA CORPORATION COMMISSION
UTILITIES DIVISION

ANNUAL REPORT

Of

Company Name: **Arizona Water Company**
PO Box 29006

Mailing Address: Phoenix AZ
85038-9006

Docket No.: W-01445A

For the Year Ended: 12/31/22

WATER UTILITY

To

Arizona Corporation Commission

Due on April 15th

Email: Util-Compliance@azcc.gov, mail or deliver the completed Annual Report to:

Arizona Corporation Commission
Compliance Section - Utilities Division
1200 West Washington Street
Phoenix, Arizona 85007

Application Type: Original Filing

Application Date: 4/14/2023

ARIZONA CORPORATION COMMISSION
 WATER UTILITY ANNUAL REPORT
 Arizona Water Company
 A Class Utility

For the Calendar Year Ended: 12/31/22

Primary Address:
 City: State: Zip Code:

Telephone Number:

Date of Original Organization of Utility:

Person to whom correspondence should be addressed concerning this report:

Name:
 Telephone No. :
 Address:
 City: State: Zip Code:
 Email:

Name:
 Telephone No. :
 Address:
 City: State:
 Zip Code:
 Email:

Name:
 Telephone No. :
 Address:
 City: State:
 Zip Code:
 Email:

Name:
 Telephone No. :
 Address:
 City: State:
 Zip Code:
 Email:

Name:
 Telephone No. :
 Address:
 City: State:
 Zip Code:
 Email:

Ownership:

Counties Served:

Important changes during the year

No	For those companies not subject to the affiliated interest rules, has there been a change in ownership or direct control during the year?
	If yes, please provide specific details in the box below.
	N/A

No	Has the company been notified by any other regulatory authorities during the year, that they are out of compliance?
	If yes, please provide specific details in the box below.
	N/A

Utility Plant in Service (Water)							
Account No.	Description	Beginning Year Original Cost	Current Year Additions	Current Year Retirements	Adjusted Original Cost	Accumulated Depreciation	OCLD (OC less AD)
301	Organization	\$651	\$0	\$0	\$651		\$651
302	Franchises	127,258	3,480		130,738		130,738
303	Land and Land Rights	17,405,860	5,962,328	203	23,367,985		23,367,985
304	Structures and Improvements	16,366,361	9,994,931	712,566	25,648,726	2,560,704	23,088,021
305	Collecting & Improving Reservoirs	4,676,682	155,621		4,832,303	378,109	4,454,194
306	Lake, River, Canal Intakes	2,599,572			2,599,572	219,102	2,380,470
307	Wells and Springs	33,534,641	396		33,535,036	13,944,820	19,590,216
308	Infiltration Galleries				0		0
309	Supply Mains				0		0
310	Power Generation Equipment				0		0
311	Pumping Equipment	63,027,902	3,609,203	589,617	66,047,487	28,126,042	37,921,445
320	Water Treatment Equipment				0		0
320.1	Water Treatment Plants	73,237,196	3,251,491	2,284	76,486,403	22,772,385	53,714,017
320.2	Solution Chemical Feeders				0		0
320.3	Point-of-Use Treatment Devices				0		0
330	Distribution Reservoirs and Standpipes				0		0
330.1	Storage Tanks	25,741,162	2,133,681		27,874,843	7,698,176	20,176,667
330.2	Pressure Tanks				0		0
331	Transmission and Distribution Mains	263,272,631	17,438,536	187,162	280,524,005	87,453,440	193,070,565
333	Services	88,329,437	7,009,359	303,763	95,035,034	42,441,731	52,593,303
334	Meters and Meter Installations	17,028,277	1,989,463	449,265	18,568,474	5,401,151	13,167,324
335	Hydrants	22,627,891	997,654	9,739	23,615,806	8,544,772	15,071,033
336	Backflow Prevention Devices				0		0
339	Other Plant and Misc. Equipment				0		0
340	Office Furniture and Equipment	7,947,961	257,008		8,204,968	5,657,638	2,547,331
340.1	Computer & Software				0		0
341	Transportation Equipment				0		0
342	Stores Equipment	140,034	5,082		145,116	81,029	64,087
343	Tools, Shop and Garage Equipment	2,359,815	346,729		2,706,544	1,114,272	1,592,272
344	Laboratory Equipment	395,338	16,568		411,906	232,845	179,061
345	Power Operated Equipment	710,912	515,205		1,226,117	419,762	806,355
346	Communication Equipment	7,969,665	933,547		8,903,213	6,109,264	2,793,949
347	Miscellaneous Equipment	594,311	245,408		839,719	388,594	451,125
348	Other Tangible Plant				0		0
	Totals	\$648,093,556	\$54,865,689	\$2,254,600	\$700,704,645	\$233,543,835	\$467,160,810

Depreciation Expense for the Current Year (Water)									
Account No.	Description	Beginning Year Original Cost	Current Year Additions	Current Year Retirements	Adjusted Original Cost	Fully Depreciated/Non-depreciable Plant	Depreciable Plant	Depreciation Percentages	Depreciation Expense
301	Organization	\$651	\$0	\$0	\$651		\$651	0.00%	\$0
302	Franchises	127,258	3,480	0	130,738		130,738	0.00%	0
303	Land and Land Rights	17,405,860	5,962,328	203	23,367,985	20,934,231	2,433,754	0.00%	0
304	Structures and Improvements	16,366,361	9,994,931	712,566	25,648,726		25,648,726	3.74%	784,885
305	Collecting & Improving Reservoirs	4,676,682	155,621	0	4,832,303		4,832,303	2.50%	118,862
306	Lake, River, Canal Intakes	2,599,572	0	0	2,599,572		2,599,572	2.50%	64,989
307	Wells and Springs	33,534,641	396	0	33,535,036		33,535,036	2.72%	911,960
308	Infiltration Galleries	0	0	0	0		0		0
309	Supply Mains	0	0	0	0		0		0
310	Power Generation Equipment	0	0	0	0		0		0
311	Pumping Equipment	63,027,902	3,609,203	589,617	66,047,487		66,047,487	5.30%	3,422,639
320	Water Treatment Equipment	0	0	0	0		0		0
320.1	Water Treatment Plants	73,237,196	3,251,491	2,284	76,486,403		76,486,403	3.99%	2,987,693
320.2	Solution Chemical Feeders	0	0	0	0		0		0
320.3	Point-of-Use Treatment Devices	0	0	0	0		0		0
330	Distribution Reservoirs and Standpipes	0	0	0	0		0		0
330.1	Storage Tanks	25,741,162	2,133,681	0	27,874,843		27,874,843	1.83%	490,323
330.2	Pressure Tanks	0	0	0	0		0		0
331	Transmission and Distribution Mains	263,272,631	17,438,536	187,162	280,524,005		280,524,005	1.79%	4,862,388
333	Services	88,329,437	7,009,359	303,763	95,035,034		95,035,034	2.99%	2,744,163
334	Meters and Meter Installations	17,028,277	1,989,463	449,265	18,568,474		18,568,474	5.77%	1,027,442
335	Hydrants	22,627,891	997,654	9,739	23,615,806		23,615,806	2.02%	466,457
336	Backflow Prevention Devices	0	0	0	0		0		0
339	Other Plant and Misc. Equipment	0	0	0	0		0		0
340	Office Furniture and Equipment	7,947,961	257,008	0	8,204,968		8,204,968	5.98%	483,106
340.1	Computer & Software	0	0	0	0		0		0
341	Transportation Equipment	0	0	0	0		0		0
342	Stores Equipment	140,034	5,082	0	145,116		145,116	4.19%	5,970
343	Tools, Shop and Garage Equipment	2,359,815	346,729	0	2,706,544		2,706,544	3.96%	100,367
344	Laboratory Equipment	395,338	16,568	0	411,906		411,906	4.83%	19,495
345	Power Operated Equipment	710,912	515,205	0	1,226,117		1,226,117	5.50%	53,234
346	Communication Equipment	7,969,665	933,547	0	8,903,213		8,903,213	6.08%	513,273
347	Miscellaneous Equipment	594,311	245,408	0	839,719		839,719	4.24%	30,404
348	Other Tangible Plant	0	0	0	0		0		0
	Subtotal	\$648,093,556	\$54,865,689	\$2,254,600	\$700,704,645	\$20,934,231	\$679,770,414		\$19,087,650

Contribution(s) in Aid of Construction (Gross)	\$177,117,693
Less: Non Amortizable Contribution(s)	
Fully Amortized Contribution(s)	35,105,576
Amortizable Contribution(s)	\$142,012,117
Times: Proposed Amortization Rate	2.64%
Amortization of CIAC	\$3,752,879

Less: Amortization of CIAC **\$3,752,879**

DEPRECIATION EXPENSE \$15,334,771

Arizona Water Company
Annual Report
Balance Sheet Assets
12/31/22

Balance Sheet Assets				
	Assets		Balance at Beginning of Year (2022)	Balance at End of Year (2022)
Account No.	Current and Accrued Assets			
131	Cash		\$65,976,047	\$47,294,468
134	Working Funds		9,950	52,039
135	Temporary Cash Investments		0	10,550
141	Customer Accounts Receivable		5,835,139	5,313,082
146	Notes Receivable from Associated Companies		0	0
151	Plant Material and Supplies		539,848	695,020
162	Prepayments		2,201,756	2,224,584
174	Miscellaneous Current and Accrued Assets		17,977,459	16,061,722
	Total Current and Accrued Assets		\$92,540,199	\$71,651,464
Account No.	Fixed Assets			
101	Utility Plant in Service*		\$648,093,556	\$700,704,645
103	Property Held for Future Use		1,581,755	2,445,126
105	Construction Work in Progress		33,315,738	44,855,833
108	Accumulated Depreciation (enter as negative)*		(222,980,554)	(233,543,835)
121	Non-Utility Property		15,749	15,749
122	Accumulated Depreciation - Non Utility		0	0
	Total Fixed Assets		\$460,026,244	\$514,477,518
	Total Assets		\$552,566,443	\$586,128,982

*Note these items feed automatically from AR3 UPIS Page 4

Arizona Water Company
Annual Report
Balance Sheet Liabilities and Owners Equity

Balance Sheet Liabilities and Owners Equity				
	Liabilities		Balance at Beginning of Year (2022)	Balance at End of Year (2022)
Account No.	Current Liabilities			
231	Accounts Payable		\$17,996,464	\$17,456,472
232	Notes Payable (Current Portion)		0	0
234	Notes Payable to Associated Companies		0	0
235	Customer Deposits		2,294,312	2,547,624
236	Accrued Taxes		2,507,218	3,201,924
237	Accrued Interest		1,899,642	1,900,277
242	Miscellaneous Current and Accrued Liabilities		(15,453)	4,214,625
	Total Current Liabilities		\$24,682,183	\$29,320,922
	Long Term Debt			
224	Long Term Debt (Notes and Bonds)		\$105,000,000	\$105,000,000
	Deferred Credits			
251	Unamortized Premium on Debt		\$0	\$0
252	Advances in Aid of Construction		26,760,307	35,120,198
255	Accumulated Deferred Investment Tax Credits		57,882,553	73,304,147
271	Contributions in Aid of Construction		176,489,958	179,535,906
272	Less: Amortization of Contributions		(35,105,576)	(38,859,612)
281	Accumulated Deferred Income Tax		53,538,913	54,409,516
	Total Deferred Credits		\$279,566,155	\$303,510,155
	Total Liabilities		\$409,248,338	\$437,831,077
	Capital Accounts			
201	Common Stock Issued		\$2,700,000	\$2,700,000
211	Other Paid-In Capital		37,323,347	37,323,347
215	Retained Earnings		103,294,758	108,274,558
218	Proprietary Capital (Sole Props and Partnerships)		0	0
	Total Capital		\$143,318,105	\$148,297,905
	Total Liabilities and Capital		\$552,566,443	\$586,128,982

Note: Total liabilities and Capital must match total assets for the beginning and end of the year!

Arizona Water Company
Annual Report
Water Comparative Income Statement
12/31/22

Water Comparative Income Statement			
Account No.	Calendar Year	Current Year 01/01/2022 - 12/31/2022	Last Year 01/01/2021 - 12/31/2021
	Operating Revenue		
461	Metered Water Revenue	\$88,158,656	\$86,259,829
460	Unmetered Water Revenue	1,541,041	1,473,823
462	Fire Protection Revenue	475,781	439,024
469	Guaranteed Revenues (Surcharges)	0	0
471	Miscellaneous Service Revenues	260,105	308,059
474	Other Water Revenue	3,689,716	4,118,750
	Total Revenues	\$94,125,300	\$92,599,485
	Operating Expenses		
601	Salaries and Wages	\$14,477,134	\$13,652,545
604	Employee Pensions and Benefits	3,678,661	3,527,572
610	Purchased Water	4,747,462	4,462,849
615	Purchased Power	6,461,210	6,046,155
618	Chemicals	1,174,866	928,993
620	Materials and Supplies	0	0
620.1	Repairs and Maintenance	1,399,210	1,284,693
620.2	Office Supplies and Expense	411,972	345,239
630	Contractual Services		
631	Contractual Services - Engineering	27,312	9,188
632	Contractual Services - Accounting	123,460	113,254
633	Contractual Services - Legal	156,067	352,328
634	Contractual Services - Management Fees	0	0
635	Contractual Services - Water Testing	412,295	443,276
636	Contractual Services - Other	5,948,755	5,583,662
640	Rents	0	
641	Rental of Building/Real Property	597,652	524,183
642	Rental of Equipment	151,082	173,575
650	Transportation Expenses	2,563,250	2,182,906
657	Insurance - General Liability	1,401,917	1,199,002
657.1	Insurance - Health and Life	129,823	
665	Regulatory Commission Expense - Rate	152,776	599,414
670	Bad Debt Expense	94,807	95,590
675	Miscellaneous Expense	1,081,348	1,457,135
403	Depreciation Expense (From Schedule AR4)	15,334,771	13,768,896
408	Taxes Other Than Income	9,295,196	9,125,299
408.11	Property Taxes	3,135,520	3,203,072
409	Income Taxes	4,675,635	5,015,404
427.1	Customer Security Deposit Interest		116,410
	Total Operating Expenses	\$77,632,181	\$74,210,640
	Operating Income / (Loss)	\$16,493,119	\$18,388,845
	Other Income / (Expense)		
419	Interest and Dividend Income	\$470,635	\$45,550
421	Non-Utility Income	914,261	352,621
426	Miscellaneous Non-Utility (Expense)		1,003,821
427	Interest (Expense)	(5,848,517)	(6,114,500)
	Total Other Income / (Expense)	(\$4,463,621)	(\$4,712,508)
	Net Income / (Loss)	\$12,029,498	\$13,676,337

Full time equivalent employees

	Direct Company	Allocated	Outside service	Total
President	1.0			1.0
Vice-president	6.0			6.0
Manager	9.0			9.0
Engineering Staff	22.0			22.0
System Operator(s)	125.0			125.0
Meter reader	25.0			25.0
Customer Service	33.0			33.0
Accounting	7.0			7.0
Business Office	13.0			13.0
Rates Department	1.0			1.0
Administrative Staff	6.0			6.0
Other	1.0			1.0
Total	249.0	0.0	0.0	249.0

Arizona Water Company
 Annual Report
 Supplemental Financial Data (Long-Term Debt)
 12/31/22

Supplemental Financial Data (Long-Term Debt)				
	Loan #1	Loan #2	Loan #3	Loan #4
Date Issued	4/12/2001	8/25/2006	9/24/2008	11/18/2019
Source of Loan	General Mortgage Bonds			
ACC Decision No.	63418	68694	70392	77415
Reason for Loan	Debt Retirement and Capital Expenditures			
Dollar Amt. Issued	\$15,000,000	\$25,000,000	\$35,000,000	\$30,000,000
Amount Outstanding	\$15,000,000	\$25,000,000	\$35,000,000	\$30,000,000
Date of Maturity	4/1/2031	8/1/2036	9/1/2038	11/1/2049
Interest Rate	8.04%	6.30%	6.67%	3.33%
Current Year Interest	\$1,206,000	\$1,575,000	\$2,334,500	\$999,000
Current Year Principal	\$0	\$0	\$0	\$0

Meter Deposit Balance at Test Year End:	\$3,742,743
---	-------------

Meter Deposits Refunded During the Test Year:	\$373,606
---	-----------

List all bonds, notes, loans, and other types of indebtedness in which the proceeds were used in the provision of public utility service. Indebtedness incurred for personal uses by the owner of the utility should not be listed. Input 0 or none if there is nothing to report for that cell.

Well and Water Usage

Name of the System:											
ADEQ Public Water System Number:											
ADWR PCC Number:											
Well registry 55# (55-XXXXXX):	Pump Horsepower	Pump Yield (gpm)	Casing Depth (feet)	Casing Diameter (inches)	Pump Motor Type**	Year Drilled	Water level 2012	Water level 2022	Meter Size (inches)	How measured:	Active

Name of system water delivered to:

ADWR PCC Number:

Source of water delivered to another system:

Name of system water received from:

ADWR PCC Number:

Source of water received:

Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January							
February							
March							
April							
May							
June							
July							
August							
September							
October							
November							
December							
Totals	0.00	0.00	0.00	0.00	0.00	\$0	0

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
2 Water sold - Total gallons from customer meters, and other sales such as construction water.
3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
6 Enter the total purchased power costs for the power meters associated with this system.
7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Superstition (Apache Junction)
 11-004
 91-000519.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #12	55-616591	300	560	852	14	Vertical	1970	600'	622'	8	Meter	yes
Well #14	55-616589	200	640	1000	20	Submersible	1979	576'	573'	8	Meter	yes
Well #15	55-565551	400	1225	1467	16	Vertical	1998	617'	628'	8	Meter	yes
Well #16	55-572660	600	2620	1510	18	Vertical	2000	596'	608'	12	Meter	yes
Well #18	55-210431	350	1250	1450	18	Vertical	2007	596'	618'	8	Meter	yes
Well #13	55-616590	600	2500	900	20	Vertical	1976	572'	582'	12	Meter	yes
Well #19	55-212858	600	2870	1300	18	Vertical	2007	574'	578'	12	Meter	yes
Well #17/#3	55-579701	250	940	1100	16	Vertical	2001	574'	568'	6	Meter	Yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:	Superior
ADWR PCC Number:	91-000528.0000
Source of water delivered to another system	Comingled

Name of system water received from:	
ADWR PCC Number:	
Source of water received	
Well registry 55# (55-XXXXXX):	

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	193,755,000	180,927,700	10,490,760	-	398,938	\$ 9,074.52	127,497
February	197,897,000	182,993,100	8,291,610	-	509,920	\$ 7,762.28	91,290
March	201,527,000	177,625,000	8,197,128	-	518,919	\$ 9,223.45	125,601
April	271,867,000	192,582,100	14,537,196	-	636,900	\$ 8,806.11	116,597
May	271,278,000	200,175,200	11,510,514	-	688,892	\$ 15,240.85	134,046
June	266,762,000	241,808,000	14,530,680	-	538,916	\$ 14,206.22	177,283
July	263,787,000	245,057,700	14,032,206	-	631,901	\$ 17,228.94	205,144
August	258,398,000	210,249,900	12,601,944	-	806,274	\$ 14,881.13	159,527
September	229,328,000	219,752,300	11,761,380	-	535,916	\$ 6,503.58	56,783
October	234,948,000	198,068,000	9,835,902	-	667,895	\$ 4,693.59	52,017
November	218,917,000	192,747,300	8,337,222	-	634,901	\$ 4,686.23	38,628
December	187,273,000	187,209,860	7,027,506	-	674,894	\$ 9,007.41	69,104
Totals	2,795,737,000	2,429,196,160	131,154,048	-	7,244,266	\$ 121,314.31	1,353,516

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11A-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Cochise (Bisbee)
 02-001
 91-000024.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #2	55-616586	10	80	333	16	Submersible	1954	127'	163'	6	meter	yes
Well #3	55-616585	100	670	270	16	Turbine	1956	124'	163'	10	meter	yes
Well #4	55-616584	100	800	337	16	Turbine	unknown	120'	120'	10	meter	yes
Well #5	55-590620	100	700	1183	16	Turbine	2002	302'	142'	6	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
 ADWR PCC Number:
 Source of water delivered to another system

Name of system water received from:
 ADWR PCC Number:
 Source of water received
 Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	22,531,600	14,111,100	-	-	197,569	\$ 17,196.02	143,759
February	21,258,000	13,335,800	-	-	173,973	\$ 16,782.87	132,388
March	23,744,000	17,060,500	-	-	540,015	\$ 16,659.17	141,106
April	31,525,000	19,125,500	-	-	781,528	\$ 18,917.75	155,620
May	32,658,000	22,876,300	-	-	162,425	\$ 22,286.40	192,581
June	30,436,000	28,664,000	-	-	211,567	\$ 23,787.22	213,970
July	23,138,000	18,887,100	-	-	237,963	\$ 21,018.87	170,200
August	22,826,000	16,902,600	-	-	247,401	\$ 18,009.25	135,976
September	22,828,000	16,723,000	-	-	229,564	\$ 18,262.03	138,687
October	22,194,000	14,707,100	-	-	314,671	\$ 17,914.32	138,627
November	21,128,000	15,017,950	-	-	164,474	\$ 17,976.75	138,255
December	18,897,000	12,760,700	-	-	189,070	\$ 15,434.59	118,288
Totals	293,163,600	210,171,650	-	-	3,450,220	\$ 224,245.24	1,819,457

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11B-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Cochise (Sierra Vista)
 02-004
 91-000025.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well VM1	55-616673	75	292	501	12	Vert Turbine	1975	460'	465'	4	meter	yes
Well VM2	55-616674	75	215	605	16	Submersible	1965	410'	430'	4	meter	yes
Sulger West Well #3	55-616679	10	100	500	12	Submersible	1972	183'	198'	3	meter	yes
Sulger East Well #2	55-616678	5	40	n/a	8	Submersible	1964	178'	193'	1	meter	yes
Fuller Well #4	55-616675	60	170	1250	18	Vert Turbine	1997	471'	502'	8	meter	yes
Well #5	55-616676	250	615	950	16	Vert Turbine	1978	406'	396'	8	meter	yes
Well #6	55-561775	100	420	1500	16	Submersible	1997	445'	453'	6	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
 ADWR PCC Number:
 Source of water delivered to another system

Name of system water received from:
 ADWR PCC Number:
 Source of water received
 Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	23,243,000	21,133,400	-	-	190,920	\$ 12,745.59	96,039
February	21,487,000	21,140,600	-	-	423,434	\$ 12,394.40	93,507
March	24,661,000	21,856,300	-	-	284,555	\$ 13,553.03	98,464
April	35,853,000	21,838,700	-	-	303,852	\$ 16,043.20	113,077
May	35,560,000	28,793,100	-	-	377,541	\$ 19,734.52	225,399
June	32,503,000	33,562,400	-	-	264,159	\$ 20,855.38	145,999
July	26,167,000	30,122,700	-	-	274,857	\$ 19,542.15	128,318
August	26,408,000	23,827,100	-	-	790,876	\$ 15,663.09	114,468
September	26,087,000	25,526,100	-	-	521,318	\$ 19,121.55	115,085
October	23,513,000	23,682,400	-	-	479,325	\$ 20,598.54	105,465
November	20,837,000	20,108,050	-	-	415,135	\$ 25,495.20	98,339
December	19,014,000	19,312,500	-	-	267,018	\$ 15,391.37	88,467
Totals	315,333,000	290,903,350	-	-	4,592,991	\$ 211,138.02	1,422,628

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11C-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Pinal Valley (Casa Grande/Coolidge)
 11-009
 91-000521.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #30	55-208822	200	720	1000	18	Turbine	2006	291'	422'	8	Meter	Y
Well #31	55-210294	250	1045	1500	18	Turbine	2006	280'	338'	10	Meter	Y
Well #13	55-212419	300	1600	2000	18	Submersible	2007	n/a	188'	10	Meter	Y
Well #33	55-212523	300	1370	1000	18	Turbine	2007	279'	343'	10	Meter	Y
Well #32	55-214248	300	1470	1200	18	Turbine	2007	271'	336'	10	Meter	Y
Well #35	55-230215	200	1000	1060	20	Turbine	2020	n/a	262'	8	Meter	Y
Well #36	55-231437	50	175	1341	20	Submersible	2020	n/a	366'	8	Meter	Y
Well #37	55-231438	200	1200	1450	18	Turbine	2020	n/a	353'	8	Meter	Y
Well #21	55-506809	250	680	696	20	Turbine	1983	276'	424'	6	Meter	Y
Well #23	55-522319	300	1500	1005	18	Turbine	1989	314'	355'	8	Meter	Y
Well #24	55-540306	300	920	1000	18	Turbine	1993	295'	368'	8	Meter	Y
Well #25	55-546719	300	1230	1074	18	Turbine	1995	306'	363'	8	Meter	Y
Well #26	55-560803	300	1360	1240	18	Turbine	1997	318'	361'	10	Meter	Y
Well #27	55-568553	200	455	1110	18	Turbine	1998	n/a	290'	4	Meter	Y
Well #28	55-571205	350	1350	1210	18	Turbine	1999	436'	460'	10	Meter	Y
Well #29	55-595284	250	1280	1120	18	Turbine	2004	280'	388'	10	Meter	Y
Well #34	55-616588	350	1500	1100	16	Turbine	1969	n/a	458'	10	Meter	Y
Well #17	55-616601	200	700	739	16	Turbine	1975	286'	321'	6	Meter	Y
Well #19	55-616603	300	1500	1000	20	Turbine	1980	294'	351'	10	Meter	Y
Well #20	55-616604	300	950	1000	20	Turbine	1977	304'	346'	10	Meter	Y
Well #7	55-616606	200	1100	1100	20	Turbine	1956	112'	147'	8	Meter	Y
Well #9	55-616608	200	1240	470	20	Turbine	1961	259'	265'	10	Meter	Y
Well #10	55-616609	200	840	980	20	Turbine	1978	246'	216'	12	Meter	Y
Well #2	55-616687	40	250	542	8	Submersible	1971	208'	246'	4	Meter	Y
Well #1	55-616686	30	140	n/a	10	Turbine	1930	190'	228'	4	Meter	Y

Name of system water delivered to:
 ADWR PCC Number:
 Source of water delivered to another system

Name of system water received from:
 ADWR PCC Number:
 Source of water received
 Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	328,670,000	351,664,000	714,992	-	4,230,438	\$ 26,660.92	253,672
February	400,657,000	331,399,900	841,956	-	3,800,305	\$ 24,010.50	208,403
March	431,127,000	354,015,500	1,118,241	-	4,421,008	\$ 27,524.54	250,356
April	506,984,000	402,924,400	1,126,040	-	4,786,651	\$ 31,847.38	288,482
May	558,931,000	442,366,300	1,167,497	304,952	4,751,856	\$ 40,563.60	378,545
June	570,511,000	527,428,100	1,681,625	142,978	8,063,938	\$ 37,337.55	340,451
July	571,002,000	581,899,000	1,642,447	127,980	5,038,411	\$ 34,137.45	306,044
August	549,990,000	473,726,000	1,563,475	4,999	4,789,750	\$ 35,804.10	310,966
September	498,747,000	690,953,400	955,714	-	4,044,367	\$ 34,972.15	308,535
October	476,608,000	445,733,800	880,846	-	3,872,894	\$ 32,514.23	283,401
November	427,152,000	387,206,620	723,519	-	4,339,471	\$ 30,129.39	262,740
December	355,314,000	352,343,630	682,237	-	4,544,789	\$ 28,746.73	264,474
Totals	5,675,693,000	5,341,660,650	13,098,590	580,909	56,683,827	\$ 384,248.54	3,456,068

If applicable, in the space below please provide a description for all un-metered water use along with amounts:
 See attached 11D-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Pinal Valley (Tierra Grande)
 11-076
 91-000548,0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #1	55-616682	75	420	496	20	Turbine	1972	150'	151'	6	meter	yes
Well #3	55-801030	25	145	379	14	Submersible	n/a	147'	192'	2	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:	Sent To:
ADWR PCC Number:	56-001307.0001 Pinal Valley - 1.78 Acre Feet
Source of water delivered to another system	Groundwater

Name of system water received from:	Received From:
ADWR PCC Number:	56-001307.0001 Pinal Valley - 2.53 Acre Feet
Source of water received	Groundwater
Well registry 55# (55-XXXXXX):	

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	4,130,000	3,790,100	-	-	261,959	\$ 2,079.23	11,812
February	3,745,000	3,558,800	-	-	36,994	\$ 1,946.84	10,332
March	4,206,000	4,048,700	-	-	37,494	\$ 1,479.71	9,375
April	5,639,000	4,082,300	-	-	166,974	\$ 1,697.38	11,379
May	4,788,000	4,075,500	304,952	148,977	34,995	\$ 2,295.34	14,451
June	4,634,000	4,685,000	142,978	142,978	32,995	\$ 1,711.46	11,659
July	4,528,000	4,660,200	127,980	131,979	264,959	\$ 1,750.64	12,099
August	3,820,000	3,552,500	4,999	400,937	166,974	\$ 2,043.14	13,039
September	3,999,000	3,641,200	-	-	28,995	\$ 1,566.19	7,480
October	3,980,000	3,778,400	-	-	124,481	\$ 1,708.97	11,420
November	4,100,000	3,913,500	-	-	27,996	\$ 1,692.06	9,039
December	3,770,000	3,662,100	-	-	22,996	\$ 1,432.75	9,332
Totals	51,339,000	47,448,300	580,909	824,871	1,207,811	\$ 21,403.71	131,416

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11E-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Pinal Valley (Stanfield)
 11-012
 91-000522.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #1	55-616684	100	280	811	16	Turbine	1963	569'	550'	4	meter	yes
Well #3	55-526586	60	195	1002	18	Submersible	1990	557'	561'	3	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
ADWR PCC Number:
Source of water delivered to another system

Name of system water received from:
ADWR PCC Number:
Source of water received
Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	2,947,000	2,559,500	-	-	112,982	\$ 2,499.70	18,600
February	2,823,000	2,756,200	-	-	102,984	\$ 2,837.80	22,449
March	3,139,000	2,900,000	-	-	119,981	\$ 2,615.17	19,704
April	5,650,000	2,968,300	-	-	116,582	\$ 2,720.16	75,059
May	4,390,000	3,546,400	-	-	112,982	\$ 2,739.80	26,618
June	4,348,000	3,851,900	-	-	109,983	\$ 4,081.64	28,214
July	4,069,000	4,501,500	-	-	114,982	\$ 3,333.80	26,461
August	4,501,000	3,439,000	-	-	99,984	\$ 3,082.97	23,895
September	4,313,000	4,342,000	-	-	116,982	\$ 3,731.18	28,977
October	3,935,000	3,957,900	-	-	114,982	\$ 3,447.53	26,205
November	3,281,000	3,055,700	-	-	106,983	\$ 3,080.00	8,467
December	3,004,000	2,937,000	-	-	94,985	\$ 2,795.30	19,486
Totals	46,400,000	40,815,400	-	-	1,324,393	\$ 36,965.05	324,134

If applicable, in the space below please provide a description for all un-metered water use along with amounts:
See attached 11F-1 for detailed information

- | |
|---|
| 1 Water withdrawn - Total gallons of water withdrawn from pumped sources. |
| 2 Water sold - Total gallons from customer meters, and other sales such as construction water. |
| 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems. |
| 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems. |
| 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft. |
| 6 Enter the total purchased power costs for the power meters associated with this system. |
| 7 Enter the total purchased kWh used by the power meters associated with this system. |

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - White Tank
 07-128
 91-000237.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #2	55-616689	40	155	477	6	Submersible	unknown	273'	317'	3	meter	yes
Well #4	55-616691	75	390	604	12	Submersible	1969	282'	n/a	4	meter	yes
Well #8	55-584393	75	160	1000	12	Submersible	2001	320'	320'	4	meter	yes
Well #7	55-616693	100	410	858	20	Turbine	unknown	204'	n/a	4	meter	no
Well #9	55-203266	250	1490	1418	16	Turbine	2004	205'	190'	10	meter	yes
Well #10	55-201426	250	1060	1288	16	Turbine	2004	182'	n/a	8	meter	yes
Well #11	55-221100	300	1250	1080	6	Turbine	2012	n/a	283'	10	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
ADWR PCC Number:
Source of water delivered to another system

Name of system water received from: Epcor Inc
ADWR PCC Number:
Source of water received - CAP Water
Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	37,521,000	44,330,000	-	-	1,153,619	\$ 25,487.03	176,944
February	47,781,000	41,026,900	-	-	2,230,051	\$ 28,100.54	185,773
March	52,357,000	44,677,300	-	-	2,270,445	\$ 26,292.35	147,469
April	74,953,000	53,640,500	-	-	2,350,232	\$ 27,244.14	164,233
May	82,228,000	59,360,200	-	-	402,737	\$ 33,442.00	193,133
June	82,280,000	70,696,700	-	-	1,833,013	\$ 38,275.33	239,565
July	82,426,000	79,853,900	-	-	2,122,668	\$ 41,302.02	266,680
August	78,698,000	69,998,900	-	-	2,150,563	\$ 38,496.38	245,137
September	71,087,000	69,416,800	-	-	1,301,826	\$ 38,961.28	258,725
October	67,387,000	62,868,400	-	-	1,970,931	\$ 34,341.16	214,498
November	56,939,000	51,699,928	-	-	1,024,340	\$ 26,290.36	165,145
December	49,762,000	51,386,814	-	-	1,064,333	\$ 26,515.51	170,737
Totals	783,419,000	698,956,342	-	-	19,874,759	\$ 384,748.10	2,428,039

If applicable, in the space below please provide a description for all un-metered water use along with amounts:
See attached 11G-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Ajo
 10-003
 91-000412.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Water Level 10/1/2022	Meter Size (inches)	How Measured	Active
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
ADWR PCC Number:
Source of water delivered to another system

Name of system water received from:	Ajo Improvement Company
ADWR PCC Number:	
Source of water received	
Well registry 55# (55-XXXXXX):	

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	2,921,000	2,849,100	-	2,919,168	20,997	\$ 315.92	2,207
February	3,059,000	2,590,600	-	3,059,262	25,696	\$ 317.64	2,235
March	3,828,000	3,037,400	-	3,828,150	69,189	\$ 347.61	2,501
April	3,580,000	3,038,500	-	3,580,542	26,496	\$ 461.16	1,901
May	4,055,000	3,158,000	-	4,052,952	30,495	\$ 430.34	3,310
June	3,908,000	3,747,300	-	3,906,342	36,994	\$ 714.91	3,449
July	4,027,000	4,057,000	-	4,026,888	36,494	\$ 806.93	4,478
August	3,556,000	2,821,500	-	3,554,478	32,495	\$ 438.20	3,635
September	3,572,000	3,444,900	-	3,570,768	24,996	\$ 478.17	6,221
October	3,361,000	3,057,600	-	3,358,998	28,096	\$ 430.16	2,935
November	3,135,000	3,012,800	-	3,134,196	126,480	\$ 364.96	6,346
December	2,583,000	2,514,800	-	2,583,594	27,496	\$ 260.78	1,650
Totals	41,585,000	37,329,500	-	41,575,338	485,924	\$ 5,366.78	40,868

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11H-1 for detailed information

1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
 6 Enter the total purchased power costs for the power meters associated with this system.
 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Casa Grande South
 11-061
 91-000545.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Water Level Oct-22	Meter Size (inches)	How Measured	Active
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
ADWR PCC Number:
Source of water delivered to another system

Name of system water received from:	Pinal Valley
ADWR PCC Number:	91-000521.0000
Source of water received	Groundwater
Well registry 55# (55-XXXXXX):	

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	682,344	656,100	-	680,922	2,000	\$ 1,686.38	16,992
February	723,632	695,800	-	723,276	2,000	\$ 2,097.07	21,788
March	880,984	847,100	-	879,660	2,000	\$ 1,805.34	18,670
April	955,864	919,100	-	954,594	2,000	\$ 2,092.00	21,910
May	1,162,720	1,118,000	-	1,163,106	2,000	\$ 1,694.74	17,377
June	1,510,704	1,452,600	-	1,511,712	8,399	\$ 2,083.64	21,539
July	1,538,888	1,479,700	-	1,537,776	2,000	\$ 1,215.02	11,882
August	1,018,680	979,500	-	1,019,754	2,000	\$ 1,643.34	16,628
September	1,126,216	1,082,900	-	1,127,268	2,000	\$ 1,994.38	20,471
October	1,118,416	1,075,400	-	1,117,494	2,000	\$ 1,145.14	11,278
November	842,088	809,700	-	840,564	2,000	\$ 1,070.77	10,598
December	715,104	687,600	-	713,502	2,000	\$ 1,015.99	10,207
Totals	12,275,640	11,803,500	-	12,269,628	-	\$ 19,543.81	199,338

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11I-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #2	55-808096	40	200	584	16	Turbine	1955	n/a	401'	4	Meter	Y

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
ADWR PCC Number:
Source of water delivered to another system

Name of system water received from:
ADWR PCC Number:
Source of water received
Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	2,151,000	1,858,500	-	-	13,998	\$ 1,079.56	8,933
February	2,416,000	2,032,600	-	-	17,497	\$ 1,019.94	7,988
March	2,056,000	1,785,600	-	-	45,593	\$ 1,047.14	8,259
April	3,730,000	2,061,600	-	-	21,397	\$ 1,137.40	9,225
May	3,154,000	2,214,700	-	-	15,997	\$ 1,233.10	10,332
June	3,091,000	3,053,700	-	-	17,997	\$ 1,330.59	11,414
July	2,852,000	2,734,600	-	-	16,497	\$ 1,445.04	12,729
August	2,950,000	2,290,700	-	-	41,993	\$ 1,279.71	10,833
September	2,836,000	2,541,700	-	-	21,197	\$ 1,267.05	10,727
October	2,495,000	2,500,600	-	-	192,170	\$ 1,339.51	11,484
November	2,111,000	1,901,580	-	-	12,998	\$ 1,153.40	9,295
December	1,924,000	1,690,440	-	-	11,998	\$ 1,090.03	8,510
Totals	31,766,000	26,666,320	-	-	429,333	\$ 14,422.47	119,729

If applicable, in the space below please provide a description for all un-metered water use along with amounts:
See attached 11J-1 for detailed information

- | |
|---|
| 1 Water withdrawn - Total gallons of water withdrawn from pumped sources. |
| 2 Water sold - Total gallons from customer meters, and other sales such as construction water. |
| 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems. |
| 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems. |
| 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft. |
| 6 Enter the total purchased power costs for the power meters associated with this system. |
| 7 Enter the total purchased kWh used by the power meters associated with this system. |

Company Name:

Arizona Water Company - Pinal Valley (Coolidge Airport)
(System is leased from the City of Coolidge)

ADEQ Public Water System No:

11-707

ADWR PCC Number:

n/a

Year Ended:

12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Water Level 10/1/2022	Meter Size (inches)	How Measured	Active
Well #1	55-620899	50	350	475	12	Turbine	1942	n/a	337'	4	meter	yes
Well #2	55-620900	50	320	435	16	Submersible	1942	n/a	332'	4	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
 ADWR PCC Number:
 Source of water delivered to another system

Name of system water received from:
 ADWR PCC Number:
 Source of water received
 Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	170,000	145,700	-	-	48,992	\$ 691.65	953
February	168,000	153,200	-	-	28,995	\$ 395.91	1,386
March	220,000	167,900	-	-	24,996	\$ 445.62	1,860
April	306,000	243,400	-	-	56,191	\$ 503.32	2,344
May	426,000	371,900	-	-	22,996	\$ 624.49	3,499
June	342,000	331,800	-	-	26,996	\$ 533.34	2,595
July	455,000	429,000	-	-	36,894	\$ 649.46	3,802
August	487,000	324,300	-	-	68,189	\$ 550.65	2,974
September	392,000	366,610	-	-	43,893	\$ 455.84	2,180
October	271,000	221,800	-	-	86,286	\$ 445.27	2,042
November	254,000	247,900	-	-	28,596	\$ 410.37	1,696
December	255,000	224,500	-	-	21,997	\$ 362.04	993
Totals	3,746,000	3,228,010	-	-	495,023	\$ 6,067.96	26,323

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11K-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Lakeside)
 09-003
 91-000365.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #2	55-616612	10	65	301	10	Submersible	1970	n/a	134'	2	meter	yes
Well #4	55-616614	50	160	760	8	Submersible	1972	639'	635'	3	meter	yes
Well #5	55-504286	125	360	1039	20	Submersible	1983	744'	753'	4	meter	yes
Well #6	55-560979	200	560	1000	18	Submersible	1997	662'	682'	8	meter	yes
Well #7	55-579779	200	500	1020	18	Turbine	2000	660'	643'	6	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
ADWR PCC Number:
Source of water delivered to another system

Name of system water received from: Poderosa Water Co
ADWR PCC Number:
Source of water received
Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	15,719,000	14,656,800	-	-	81,987	\$ 14,678.93	87,577
February	13,198,000	12,619,700	-	-	49,992	\$ 15,874.51	91,639
March	13,354,000	12,382,600	-	-	20,997	\$ 14,046.50	74,441
April	24,168,000	14,447,100	-	-	78,988	\$ 14,681.08	79,313
May	32,419,000	21,105,200	-	-	60,990	\$ 18,092.50	110,831
June	32,611,000	33,338,400	-	-	63,990	\$ 23,026.97	165,602
July	27,188,000	31,701,700	-	-	32,995	\$ 22,151.53	142,347
August	24,968,000	24,148,400	-	-	78,988	\$ 20,447.77	147,178
September	25,271,000	25,343,500	-	-	36,994	\$ 19,491.44	135,853
October	19,211,000	22,220,700	-	-	51,992	\$ 18,111.77	122,809
November	14,990,000	14,849,500	-	-	81,987	\$ 16,860.92	97,853
December	15,214,000	13,170,600	-	-	47,992	\$ 15,840.07	59,689
Totals	258,311,000	239,984,200	-	-	687,892	\$ 213,303.99	1,315,132

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11L-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Pinetop Lakes)
 09-018
 91-000374.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #1	55-616643	20	120	210	8	Submersible	1970	n/a	181'	3	meter	yes
Well #2	55-506761	150	420	1230	20	Submersible	1984	1074'	1080'	4	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
ADWR PCC Number:
Source of water delivered to another system

Name of system water received from:
ADWR PCC Number:
Source of water received
Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	3,257,000	2,761,700	-	-	24,996	\$ 2,311.32	17,374
February	1,821,000	1,963,300	-	-	39,994	\$ 2,134.20	15,576
March	2,348,000	1,837,200	-	-	20,997	\$ 1,987.20	14,230
April	4,111,000	2,422,400	-	-	47,992	\$ 3,492.77	20,056
May	8,797,000	6,305,300	-	-	24,996	\$ 4,620.67	31,554
June	9,814,000	9,774,600	-	-	29,995	\$ 7,790.36	63,166
July	7,479,000	7,889,600	-	-	14,998	\$ 7,673.93	59,039
August	6,432,000	5,164,200	-	-	29,995	\$ 5,966.71	55,494
September	6,641,000	6,590,300	-	-	19,997	\$ 5,422.91	37,831
October	3,913,000	4,321,400	-	-	21,997	\$ 4,975.12	33,520
November	2,669,000	2,086,900	-	-	36,994	\$ 4,112.25	23,957
December	2,963,000	2,337,500	-	-	39,994	\$ 3,838.65	21,528
Totals	60,245,000	53,454,400	-	-	352,945	\$ 54,326.09	393,327

If applicable, in the space below please provide a description for all un-metered water use along with amounts:
See attached 11M-1 for detailed information

- | |
|---|
| 1 Water withdrawn - Total gallons of water withdrawn from pumped sources. |
| 2 Water sold - Total gallons from customer meters, and other sales such as construction water. |
| 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems. |
| 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems. |
| 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft. |
| 6 Enter the total purchased power costs for the power meters associated with this system. |
| 7 Enter the total purchased kWh used by the power meters associated with this system. |

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Overgaard)
 09-004
 91-000366.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #1	55-616639	25	78	643	10	Submersible	1971	534'	531'	2	meter	yes
Well #2	55-616640	125	350	600	16	Turbine	1966	489'	489'	4	meter	yes
Well #3	55-616641	40	145	700	12	Submersible	1960	493'	590'	3	meter	yes
Well #4	55-616642	60	240	609	10	Submersible	1971	516'	533'	4	meter	yes
Well #5	55-579785	125	480	795	16	Submersible	2000	515'	505'	4	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
 ADWR PCC Number:
 Source of water delivered to another system

Name of system water received from:
 ADWR PCC Number:
 Source of water received
 Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	10,285,000	-	-	-	161,975	\$ 5,707.74	58,750
February	7,941,000	-	-	-	60,990	\$ 8,742.34	57,718
March	7,699,000	-	-	-	87,986	\$ 8,487.88	46,313
April	13,984,000	-	-	-	112,982	\$ 9,153.51	48,263
May	22,224,000	-	-	-	149,977	\$ 9,969.24	66,810
June	24,967,000	-	-	-	69,989	\$ 12,631.45	105,379
July	18,463,000	-	-	-	73,988	\$ 11,474.58	81,319
August	15,704,000	-	-	-	141,978	\$ 10,197.34	129,383
September	15,137,000	-	-	-	87,986	\$ 9,850.73	67,117
October	11,260,000	-	-	-	91,986	\$ 8,866.87	54,578
November	8,365,000	-	-	-	123,981	\$ 8,814.60	48,403
December	7,828,000	-	-	-	88,986	\$ 8,918.66	131,704
Totals	163,857,000	-	-	-	1,252,804	\$ 112,814.94	895,737

If applicable, in the space below please provide a description for all un-metered water use along with amounts:
 See attached 11N-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Forrest Towne)
 n/a
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #1	55-616610	2	7	560	10	Submersible	unknown	451'	451'	5/8	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
 ADWR PCC Number:
 Source of water delivered to another system

Name of system water received from:
 ADWR PCC Number:
 Source of water received
 Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	20,000	-	-	-	-	\$ 120.25	700
February	22,000	-	-	-	-	\$ 133.43	835
March	16,000	-	-	-	-	\$ 108.25	511
April	28,000	-	-	-	-	\$ 82.52	246
May	29,000	-	-	-	-	\$ 83.85	220
June	32,000	-	-	-	-	\$ 96.52	357
July	24,000	-	-	-	-	\$ 81.10	176
August	24,000	-	-	-	3,258	\$ 82.78	154
September	23,000	-	-	-	-	\$ 85.27	42
October	19,000	-	-	-	-	\$ 83.40	174
November	17,000	-	-	-	-	\$ 94.21	340
December	13,000	-	-	-	-	\$ 156.89	942
Totals	267,000	-	-	-	3,258	\$ 1,208.47	4,696

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 110-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Superstition (Miami)
 04-002
 91-000117.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #11	55-616626	30	85	760	12	Submersible	1969	385'	542'	2	meter	yes
Well #12	55-616627	50	100	840	16	Submersible	1972	315'	606'	3	meter	yes
Well #17	55-616631	25	65	800	8	Submersible	1976	229'	282'	2	meter	yes
Well #18	55-616632	60	111	972	16	Submersible	1979	567'	n/a	3	meter	no
Well #19	55-616633	25	45	800	12	Submersible	1979	367'	n/a	2	meter	yes
Well #20	55-616634	30	65	1000	14	Submersible	1981	665'	595'	2	meter	yes
Well #21	55-526519	1	12	1006	18	Submersible	1990	155'	n/a	1	meter	no
Well #24	55-534905	10	25	910	6	Submersible	1992	n/a	n/a	1	meter	yes
Well #25	55-548894	30	70	900	8	Submersible	1995	390'	n/a	2	meter	yes
Well #26	55-561712	30	70	1050	8	Submersible	1998	312'	293'	2	meter	yes
Well #27	55-584245	50	260	980	12	Submersible	2000	178'	300'	6	meter	yes
Well #28	55-585052	75	330	800	12	Submersible	2001	305'	277'	6	meter	yes
Well #6	55-616621	40	101	1088	16	Submersible	1970	380'	139'	2	meter	yes
Well #7	55-616622	20	70	573	16	Submersible	1963	n/a	103'	2	meter	yes
Well #9	55-616624	10	35	777	16	Submersible	1963	470'	n/a	2	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:	City of Globe
ADWR PCC Number:	
Source of water delivered to another system	

Name of system water received from:	City of Globe
ADWR PCC Number:	0
Source of water received	0
Well registry 55# (55-XXXXXX):	0

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	21,771,800	16,912,500	329,058	201,996	43,743	20,435	159,960
February	19,987,100	15,068,300	260,640	355,122	263,659	17,982	129,489
March	17,522,000	15,202,200	276,930	413,766	69,589	19,480	137,869
April	19,779,700	20,545,400	329,058	179,190	123,181	20,211	151,664
May	28,614,300	22,820,700	345,348	215,028	89,686	22,389	167,435
June	31,589,000	27,952,000	394,218	384,444	93,585	22,592	180,283
July	26,437,700	28,507,400	417,024	446,346	112,332	26,704	221,661
August	25,537,900	22,940,500	377,928	439,830	81,687	22,221	179,169
September	26,666,200	22,259,800	296,478	449,604	75,238	20,693	156,826
October	22,275,900	22,129,100	231,318	257,382	90,186	23,276	184,961
November	20,192,100	17,356,750	224,802	172,674	237,263	18,993	148,779
December	19,226,000	15,842,450	221,544	192,222	205,868	18,512	138,376
Totals	279,599,700	247,537,100	3,704,346	3,707,604	1,486,017	253,489	1,956,472

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11P-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - San Manuel
 11-020
 91-000527.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Water Level Oct-22	Meter Size (inches)	How Measured	Active
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
 ADWR PCC Number:
 Source of water delivered to another system

Name of system water received from: BHP Copper
 ADWR PCC Number: AZ0411347
 Source of water received: Groundwater
 Well registry 55# (55-XXXXXX):

water purchased from BHP Copper

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	6,295,000	5,967,400	-	6,294,456	13,498	\$ 2,686.01	14,035
February	7,195,000	5,857,400	-	7,193,664	13,998	\$ 2,879.52	15,762
March	6,622,000	5,791,900	-	6,620,256	294,994	\$ 2,837.72	15,298
April	14,660,000	7,944,900	-	14,657,742	1,098,128	\$ 3,397.89	20,760
May	10,988,000	7,688,000	-	10,985,976	28,146	\$ 3,277.19	19,601
June	10,713,000	9,874,100	-	10,712,304	147,177	\$ 3,842.91	24,262
July	9,423,000	9,803,000	-	9,422,136	12,998	\$ 3,584.11	21,495
August	8,175,000	7,739,900	-	8,174,322	36,494	\$ 3,279.73	17,611
September	8,844,000	7,995,000	-	8,842,212	32,495	\$ 3,146.49	17,956
October	7,318,000	7,653,200	-	7,317,468	11,548	\$ 2,878.37	15,261
November	6,298,000	6,052,200	-	6,297,714	14,998	\$ 3,292.22	16,306
December	7,240,000	5,898,200	-	7,239,276	167,974	\$ 3,033.74	13,264
Totals	103,771,000	88,265,200	-	103,757,526	1,872,447	\$ 38,135.90	211,610

If applicable, in the space below please provide a description for all un-metered water use along with amounts:
 See attached 11Q-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Falcon Valley (Oracle / SaddleBrooke)
 11-019
 91-000526.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #2	55-616636	125	360	840	12	Turbine	1961	n/a	302'	6	meter	yes
Well #3	55-616638	125	420	1000	16	Turbine	1975	392'	373'	6	meter	yes
Well #4	55-522318	60	200	1200	14	Submersible	1988	n/a	384'	4	meter	yes
Well #5	55-547316	200	600	1131	12	Turbine	1995	486'	489'	6	meter	yes
Well #6	55-209389	200	590	1200	16	Turbine	2006	556'	516'	6	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
 ADWR PCC Number:
 Source of water delivered to another system

Name of system water received from:
 ADWR PCC Number:
 Source of water received
 Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	16,379,000	14,775,200	-	-	195,469	\$ 12,199.39	110,142
February	17,567,000	14,642,600	-	-	62,490	\$ 14,702.74	185,405
March	15,825,000	13,907,800	-	-	137,578	\$ 10,992.79	92,191
April	28,642,000	17,811,900	-	-	125,180	\$ 11,543.64	98,497
May	27,385,000	21,439,000	-	-	521,868	\$ 13,235.95	116,327
June	27,132,000	25,783,700	-	-	99,984	\$ 17,557.77	162,201
July	23,460,000	22,948,300	-	-	352,585	\$ 17,910.46	165,035
August	19,714,000	15,637,200	-	-	650,038	\$ 17,415.79	159,623
September	19,800,000	18,182,600	-	-	127,100	\$ 15,482.36	139,701
October	20,381,000	17,987,400	-	-	948,632	\$ 14,887.08	133,501
November	17,824,000	15,393,250	-	-	156,575	\$ 13,945.35	125,306
December	15,741,000	14,276,800	-	-	55,991	\$ 15,099.87	136,484
Totals	249,850,000	212,785,750	-	-	3,433,493	\$ 174,973.19	1,624,412

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11R-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Winkelman
 04-003
 91-000118.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #3	55-616637	20	200	200	12	Submersible	1957	22'	29'	4	meter	yes
Well #4	55-616618	30	300	120	20	Submersible	1978	21'	28'	4	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
 ADWR PCC Number:
 Source of water delivered to another system

Name of system water received from:
 ADWR PCC Number:
 Source of water received
 Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	1,300,000	1,181,400	-	-	7,999	\$ 564.65	2,697
February	1,543,000	1,335,100	-	-	144,927	\$ 651.60	3,512
March	1,796,000	1,590,600	-	-	17,997	\$ 674.13	3,766
April	4,316,000	1,989,500	-	-	61,290	\$ 725.66	4,296
May	3,300,000	2,460,900	-	-	136,879	\$ 899.19	6,125
June	3,743,000	2,894,500	-	-	46,993	\$ 1,009.94	7,032
July	3,091,000	3,822,000	-	-	626,502	\$ 1,119.70	8,295
August	2,280,000	2,336,300	-	-	40,494	\$ 859.92	5,378
September	2,743,000	2,424,200	-	-	27,296	\$ 818.80	4,991
October	1,786,000	2,306,400	-	-	24,996	\$ 818.80	4,991
November	2,078,000	1,239,000	-	-	184,371	\$ 690.65	3,559
December	1,148,000	1,841,050	-	-	15,248	\$ 765.81	4,270
Totals	29,124,000	25,420,950	-	-	1,334,991	\$ 9,598.85	58,912

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11S-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Sedona)
 03-003
 91-000083.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Sedona Well #2	55-616656	100	510	517	10	Submersible	1997	298'	312'	4	meter	yes
Sky Mountain Well #4	55-616658	25	60	750	8	Submersible	1955	593'	614'	2	meter	yes
Harmony Hills Well #5	55-616659	60	143	684	6	Submersible	1962	604'	600'	4	meter	yes
Rainbow Well #6	55-616662	60	225	18	8	Submersible	1949	507'	534'	4	meter	yes
Williams Well #7	55-616661	125	480	700	10	Turbine	1949	495'	n/a	4	meter	yes
SW Center Well #8	55-616663	250	800	791	16	Submersible	1975	569'	575'	6	meter	yes
Sedona Well #9	55-506794	150	530	707	18	Submersible	1984	n/a	205'	6	meter	yes
Broken Arrow Well #10	55-566709	100	350	1010	16	Submersible	1998	n/a	n/a	4	meter	yes
Harmony Hills Well #12	55-204279	250	800	897	16	Submersible	2004	584'	612'	6	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
 ADWR PCC Number:
 Source of water delivered to another system

Name of system water received from:
 ADWR PCC Number:
 Source of water received
 Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	59,271,000	56,078,600	-	-	114,982	\$ 38,653.36	370,441
February	59,373,000	50,383,500	-	-	155,976	\$ 33,832.88	290,453
March	64,952,000	51,535,000	-	-	528,917	\$ 43,941.69	405,850
April	98,025,000	69,195,700	-	-	219,966	\$ 45,826.59	418,341
May	107,010,000	79,039,800	-	-	208,967	\$ 31,792.68	264,462
June	113,796,000	96,477,800	-	-	219,966	\$ 58,489.35	551,046
July	105,159,000	107,404,700	-	-	169,973	\$ 56,355.85	529,479
August	96,099,000	85,647,400	-	-	240,962	\$ 53,465.19	492,954
September	90,075,000	88,514,100	-	-	157,975	\$ 52,406.73	477,367
October	85,045,000	78,928,300	-	-	147,977	\$ 40,372.22	353,346
November	70,986,000	66,925,650	-	-	301,953	\$ 44,795.05	392,116
December	58,626,000	59,054,550	-	-	162,974	\$ 38,565.95	347,109
Totals	1,008,417,000	889,185,100	-	-	2,630,588	\$ 538,497.54	4,892,964

If applicable, in the space below please provide a description for all un-metered water use along with amounts:

See attached 11T-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Valley Vista)
 13-114
 91-000663.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Rancho Rojo	55-616671	30	95	200	8	Submersible	1963	297'	303'	3	Turbo Mtr	yes
Wild Horse Mesa	55-616670	5	25	15	8	Submersible	1961	324'	329'	1	SR Mtr	yes
Sedona Golf Resort	55-518969	60	255	621	8	Submersible	1989	347'	353'	3	Turo Mtr	yes
Valley Vista Well #13	55-212110	75	420	1000	16	Submersible	2007	386'	406'	4	Turbo Mtr	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
ADWR PCC Number:
Source of water delivered to another system

Name of system water received from:
ADWR PCC Number:
Source of water received
Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	7,678,000	5,952,900	-	-	24,996	\$ 3,492.52	27,123
February	6,037,000	4,992,500	-	-	296,954	\$ 3,581.03	26,866
March	6,714,000	5,391,500	-	-	14,998	\$ 4,020.28	31,940
April	18,142,000	7,149,700	-	-	19,997	\$ 4,369.08	36,774
May	13,016,000	8,664,900	-	-	19,997	\$ 3,178.12	22,694
June	14,175,000	10,569,400	-	-	14,998	\$ 5,173.76	46,310
July	13,588,000	13,145,900	-	-	19,997	\$ 5,402.14	49,274
August	12,321,000	12,489,100	-	-	10,998	\$ 5,148.24	46,109
September	11,891,000	10,307,300	-	-	24,996	\$ 4,911.03	42,941
October	10,396,000	10,648,600	-	-	26,996	\$ 11,058.16	101,905
November	8,097,000	8,356,600	-	-	19,997	\$ 4,119.53	33,836
December	6,926,000	6,978,000	-	-	35,994	\$ 3,935.63	31,561
Totals	128,981,000	104,646,400	-	-	530,917	\$ 58,389.52	497,333

If applicable, in the space below please provide a description for all un-metered water use along with amounts:
See attached 11U-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Pinewood)
 03-002
 91-000082.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Pinewood Well #5	55-616647	50	145	1179	6	Submersible	1977	718'	699'	3	meter	yes
Pinewood Well #10	55-616651	125	320	1304	12	Submersible	1977	723'	737'	4	meter	yes
Pinewood Well #11	55-568934	125	370	1380	12	Submersible	1999	723'	740'	4	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
ADWR PCC Number:
Source of water delivered to another system

Name of system water received from:
ADWR PCC Number:
Source of water received
Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	11,920,000	4,697,100	-	-	119,981	\$ 8,396.25	64,368
February	9,914,000	2,968,200	-	-	99,984	\$ 7,866.73	54,409
March	9,545,000	3,142,400	-	-	64,990	\$ 7,912.38	54,823
April	16,414,000	3,832,100	-	-	97,985	\$ 8,401.85	61,117
May	20,996,000	7,115,200	-	-	139,978	\$ 10,100.40	74,321
June	23,864,000	15,128,100	-	-	149,977	\$ 12,891.06	107,168
July	20,317,000	18,181,700	-	-	154,976	\$ 13,918.48	119,642
August	17,821,000	12,038,100	-	-	74,988	\$ 11,629.52	91,907
September	17,245,000	11,448,600	-	-	74,988	\$ 11,272.39	87,231
October	13,585,000	9,938,600	-	-	159,975	\$ 10,461.76	77,736
November	10,197,000	5,080,650	-	-	59,991	\$ 8,381.31	58,801
December	10,511,000	3,695,350	-	-	69,989	\$ 8,413.31	58,164
Totals	182,329,000	97,266,100	-	-	1,267,802	\$ 119,645.44	909,687

If applicable, in the space below please provide a description for all un-metered water use along with amounts:
See attached 11V-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Rimrock)
 13-046
 91-000635.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #1	55-616652	15	70	116	10	Submersible	1970	163'	168'	3	meter	yes
Well #2	55-616653	30	170	209	10	Submersible	1968	108'	120'	4	meter	yes
Well #3	55-616654	n/a	n/a	380	5	n/a	1966	349'	346'	n/a	n/a	no
Well #4	55-616655	8	55	70	6	Submersible	1964	92'	100'	2	meter	yes
Well #5	55-228249	10	40	860	16	Submersible	2018	n/a	429'	2	meter	yes
MH #2	55-803288	5	25	160	5	Submersible	1969	115'	127'	2	meter	yes
MH #3	55-591459	75	340	1020	16	Submersible	2003	162'	138'	4	meter	yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
ADWR PCC Number:
Source of water delivered to another system

Name of system water received from:
ADWR PCC Number:
Source of water received
Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	5,947,000	5,015,100	-	-	14,998	\$ 3,432.09	20,130
February	6,444,000	4,333,000	-	-	11,998	\$ 3,459.61	20,463
March	5,373,000	4,349,300	-	-	20,997	\$ 3,721.95	23,129
April	9,567,000	5,557,000	-	-	14,998	\$ 4,139.88	25,944
May	9,985,000	7,472,600	-	-	19,997	\$ 4,709.82	31,473
June	9,614,000	8,897,000	-	-	36,994	\$ 4,540.46	29,729
July	8,814,000	7,806,300	-	-	18,997	\$ 4,133.75	25,915
August	8,142,000	6,089,500	-	-	9,998	\$ 4,164.81	25,707
September	7,665,000	7,130,100	-	-	11,998	\$ 3,686.21	21,497
October	6,745,000	5,592,500	-	-	19,997	\$ 3,460.57	20,242
November	5,942,000	4,725,150	-	-	10,998	\$ 3,814.63	22,627
December	5,974,000	4,572,850	-	-	13,998	\$ 3,881.06	22,990
Totals	90,212,000	71,540,400	-	-	205,968	\$ 47,144.84	289,846

If applicable, in the space below please provide a description for all un-metered water use along with amounts:
See attached 11W-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or unmetered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Superstition (Superior)
 11-021
 91-000528.0000
 12/31/2022

WATER COMPANY WELL AND WATER USAGE

Company Number	ADWR ID Number*	Pump Horsepower	Pump Yield (Gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Pump Motor Type	Year Drilled	Water Level Oct-12	Static Water Level Oct-22	Meter Size (inches)	How Measured	Active
Well #1	55-624606	100	270	780	16	Vertical	1963	583'	567'	4	Meter	Yes
Well #2	55-624607	200	560	765	16	Vertical	1960	585'	581'	4	Meter	Yes
Well #17/#3	55-579701	250	940	1100	16	Vertical	2001	574'	568'	6	Meter	Yes

*Arizona Department of Water Resources Identification Number

Name of system water delivered to:
 ADWR PCC Number:
 Source of water delivered to another system

Name of system water received from:
 ADWR PCC Number:
 Source of water received
 Well registry 55# (55-XXXXXX):

Month	Water withdrawn (gallons) ¹	Water sold (gallons) ²	Water delivered (sold) to other systems (gallons) ³	Water received (purchased) from other systems (gallons) ⁴	Estimated authorized use (gallons) ⁵	Purchased Power Expense ⁶	Purchased Power (kWh) ⁷
January	767,000	8,713,500	-	10,490,760	235,963	\$ 9,074.52	127,497
February	614,000	7,378,900	-	8,291,610	148,177	\$ 7,762.28	91,290
March	532,000	7,981,900	-	8,197,128	174,373	\$ 9,223.45	125,601
April	1,074,000	8,038,300	-	14,537,196	485,924	\$ 8,806.11	116,597
May	822,000	8,814,400	-	11,510,514	181,172	\$ 15,240.85	134,046
June	1,026,000	10,209,500	-	14,530,680	373,142	\$ 14,206.22	177,283
July	986,000	16,068,000	-	14,032,206	442,631	\$ 17,228.94	205,144
August	1,004,000	12,467,400	-	12,601,944	443,531	\$ 14,881.13	159,527
September	820,000	11,841,000	-	11,761,380	348,945	\$ 6,503.58	56,783
October	715,000	11,200,700	-	9,835,902	281,756	\$ 4,693.59	52,017
November	593,000	8,858,350	-	8,337,222	182,371	\$ 4,686.23	38,628
December	875,000	8,621,250	-	7,027,506	227,164	\$ 9,007.41	69,104
Totals	9,828,000	120,193,200	-	131,154,048	3,525,148	\$ 121,314.31	1,353,516

If applicable, in the space below please provide a description for all un-metered water use along with amounts:
 See attached 11X-1 for detailed information

- 1 Water withdrawn - Total gallons of water withdrawn from pumped sources.
- 2 Water sold - Total gallons from customer meters, and other sales such as construction water.
- 3 Water delivered (sold) to other systems - Total gallons of water delivered to other systems.
- 4 Water received (purchased) from other systems - Total gallons of water purchased/received from other systems.
- 5 Estimated authorized use - Total estimated gallons from authorized metered or un-metered use. Authorized uses such as flushing (mains, services and hydrants) draining/cleaning tanks, process, construction, fire fighting, etc. Non-authorized use (real losses) are service line breaks and leaks, water main breaks, meter inaccuracies and theft.
- 6 Enter the total purchased power costs for the power meters associated with this system.
- 7 Enter the total purchased kWh used by the power meters associated with this system.

Water Utility Plant Description	
---------------------------------	--

Name of the System:	0
ADEQ Public Water System Number:	
ADWR PCC Number:	

MAINS		
Sizes (inches)	Material	Length (feet)

CUSTOMER METERS			
Size (inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old

SERVICE LINES			
Material	Percent of system	Year installed	

BOOSTER PUMPS		
Horsepower	GPM	Quantity

FIRE HYDRANTS	
Type	Quantity
Standard *	
Other	

STORAGE TANKS			
Capacity (gallons)	Material	Quantity	Year installed

PRESSURE/BLADDER TANKS			
Capacity (gallons)	Material	Quantity	Year installed

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Water Utility Plant Description (Continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	
STRUCTURES:	
OTHER:	

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).

Use one of the following methods:

- (a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the average number of single family residence customers for the same period and divide the result by
- (b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold (Omit 000)} / 365 \text{ days} / 350 \text{ gallons per day})$

ERC

Method used:

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Superstition (Apache Junction)
 11-004
 91-000519.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	36,860
2.5	Various	0
3	Various	3,983
4	Various	131,618
6	Various	910,563
8	Various	518,415
10	Various	890
12	Various	280,324
14	Various	0
16	Various	132,721
20	Various	23,881
24	Various	30,162
36	Various	26,397

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	19,433	0.22%	0.10%
3/4	606	0.00%	0.00%
1	1,857	0.22%	1.24%
2	1	0.00%	0.00%
3	25	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5	6	0.00%	0.00%
Compound 2	231	3.45%	6.47%
Compound 3	23	2.08%	0.00%
Compound 4	22	4.35%	0.00%
Compound 6	25	12.00%	0.00%
Compound 8	2	0.00%	0.00%
Turbo 2	3	0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4	1	0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES		
Material	Percent of system	Year Installed
n/a	n/a	

BOOSTER PUMPS		
Horsepower	GPM	Quantity
2	15	1
3	20	1
5	30	2
10	25 - 500	2
15	50 - 200	2
20	175 - 350	3
25	125	1
30	300	1
40	500 - 700	7
50	310	2
75	825	4
100	1400	3
150	165 - 1250	4
200	2000	0
300	2100 - 2250	3

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
1,924	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
150,000	Steel	1	1981
250,000	Steel	1	2021
500,000	Steel	2	1973, 1986
550,000	Steel	1	1960
1,000,000	Steel	4	1977, 1987, 1990, 2002
1,400,000	Steel	1	2005
2,000,000	Steel	2	1988, 1998
4,000,000	Steel	2	1984, 1987

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
1,000	Steel	1	2004
2,000	Steel	1	1998
4,000	Steel	2	2001, 2001
5,000	Steel	2	2003, 2004
6,800	Steel	1	1998

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
ADWR FCC Number:
Year Ended:

Arizona Water Company - Superstition (Apache Junction)
11-004
91-000519.0000
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER: SCADA equipment

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
Use one of the following methods:
(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the average flow rate.
(b) If no historical flow data are available, use:
 $ERC = \frac{\text{Total SFR gallons sold (Omit 000)}}{365 \text{ days} / 350 \text{ gallons per day}}$
**ERC 196
Method used: (a)
**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account industrial

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Cochise (Bisbee)
 02-001
 91-000024.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	93,521
2.5	Various	536
3	Various	17,238
4	Various	50,652
6	Various	122,264
8	Various	28,113
10	Various	28,396
12	Various	13,239
14	Various	0
16	Various	126
20	Various	0
24	Various	2
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	3,322	0.00%	0.36%
3/4		0.00%	0.00%
1	77	0.00%	0.00%
2		0.00%	0.00%
3	2	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	47	0.00%	0.00%
Compound 3		0.00%	0.00%
Compound 4	2	0.00%	0.00%
Compound 6	1	0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2	2	0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

BOOSTER PUMPS		
Horsepower	GPM	Quantity
3	n/a	2
40	330	2
75	375	2
100	550	1
300	850	2

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
209	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
10,000	Steel	2	1976, Unknown
11,000	Steel	1	2003
100,000	Steel	3	1954, 1959, 2000
450,000	Steel	1	1983
600,000	Steel	1	1959
1,000,000	Steel	1	1955

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
200	Steel	1	2000

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - Cochise (Bisbee)
02-001
91-000024.0000
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER: SCADA equipment

[Redacted]

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
Use one of the following methods:

- (a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

- (b) If no historical flow data are available, use:
ERC = (Total SFR gallons sold (Omit 000 / 365 days / 350 gallons per day)

**ERC 118.4
Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

[Redacted]

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Cochise (Sierra Vista)
 02-004
 91-000025.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	3,966
2.5	Various	0
3	Various	11,160
4	Various	20,484
6	Various	126,370
8	Various	110,527
10	Various	0
12	Various	22,762
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	3,071	0.33%	0.78%
3/4		0.00%	0.00%
1	86	0.00%	0.00%
2		0.00%	0.00%
3	3	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	52	1.92%	0.00%
Compound 3	6	0.00%	0.00%
Compound 4	3	0.00%	0.00%
Compound 6		0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2		0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES		
Material	Percent of system	Year Installed
n/a	n/a	

BOOSTER PUMPS		
Horsepower	GPM	Quantity
7.5	n/a	3
10	n/a	3
20	n/a	1
25	n/a	2
40	n/a	4
75	n/a	1
107	n/a	1
110	n/a	1
150	n/a	1

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
266	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
10,000	Steel	1	1980
12,000	Steel	1	1982
100,000	Steel	1	1972
130,000	Steel	1	1992
250,000	Steel	1	1969
1,000,000	Steel	1	1976

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
220	Steel	1	1965
5,000	Steel	5	1973, 1974, 1974,
10,000	Steel	3	1970, 1975, 1999

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - Cochise (Sierra Vista)
02-004
91-000025.000
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER: SCADA equipment

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
Use one of the following methods:
(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

(b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold} / 365 \text{ days}) / 350 \text{ gallons per day}$

**ERC 193.2
Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Pinal Valley
 11-009
 91-000521.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	50,455
2.5	Various	0
3	Various	25,194
4	Various	327,985
6	Various	1,583,310
8	Various	785,277
10	Various	56,974
12	Various	638,564
14	Various	1,265
16	Various	164,079
20	Various	1,620
24	Various	60,237
36	Various	1,585

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	33,416	4.65%	15.62%
3/4	1,144	0.00%	0.00%
1	970	4.64%	10.31%
2	12	0.00%	0.00%
3	81	16.28%	24.81%
4	1	0.00%	0.00%
Compound 1.5	3	0.00%	0.00%
Compound 2	618	35.59%	58.40%
Compound 3	64	0.00%	0.00%
Compound 4	34	23.68%	39.47%
Compound 6	6	0.00%	0.00%
Compound 8	2	0.00%	0.00%
Turbo 2	19	0.00%	0.00%
Turbo 3	3	0.00%	0.00%
Turbo 4	3	0.00%	0.00%
Turbo 6	22	7.14%	46.43%
Turbo 8	2	0.00%	0.00%

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

BOOSTER PUMPS		
Horsepower	GPM	Quantity
7.5	70	1
10	120	3
20	180	2
25	125 - 1100	3
40	400	7
60	450 - 1000	4
75	1200	4
107	1200	1
125	1200	8
150	1500 - 2000	7
300	4000	1

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
3,481	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
16,000	Steel	1	1952
35,000	Steel	1	1963
100,000	Steel	1	1929
110,000	Steel	1	1984
116,000	Steel	1	1985
250,000	Steel	1	2009
500,000	Steel	1	1950
650,000	Steel	1	1985
900,000	Steel	1	1961
1,100,000	Steel	1	2006
1,600,000	Steel	1	2005
2,000,000	Steel	3	1969, 2012, 2018
5,000,000	Steel	2	1978, 1987

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
5,000	Steel	5	1978, 1991, 1999
6,000	Steel	2	2012, 2013

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Pinal Valley
 11-009
 91-000521.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures
-----------------------------	---------------------------------------

	Well #27 Arsenic Treatment Plant - coagulation/filtration filter vessels and ferric chloride for arsenic removal
--	--

	Well #19 (Hennes Road) Arsenic Treatment Plant-coagulation/filtration filter vessels and ferric chloride for arsenic removal
--	--

Well #9 & #10 Nitrate Treatment Plant - ion exchange filter vessels and sodium chloride regenerate for nitrate removal

Nitrate analyzers
 ferric chloride for arsenic removal
 Well #37 Arsenic Treatment Plant - coagulation/filtration filter vessels and ferric chloride for arsenic removal

STRUCTURES: wells, booster stations and storage.

OTHER: SCADA equipment
 Bridge crane and manual chain hoist
 Radio controls/base station
 Generator

19

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Pinal Valley (Tierra Grande)
 11-076
 91-000548.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	0
2.5	Various	0
3	Various	0
4	Various	1,529
6	Various	22,096
8	Various	20,549
10	Various	0
12	Various	4,911
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	355	0.00%	0.00%
3/4		0.00%	0.00%
1	7	0.00%	0.00%
2	4	0.00%	0.00%
3	1	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2		0.00%	0.00%
Compound 3		0.00%	0.00%
Compound 4		0.00%	0.00%
Compound 6		0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2	1	0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

BOOSTER PUMPS		
Horsepower	GPM	Quantity
10	120	2
50	500	1

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
6	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
10,000	Steel	1	Unknown
250,000	Steel	1	1987

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
2,000	Steel	1	1979
5,000	Steel	1	2001

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Pinal Valley (Tierra Grande)
 11-076
 91-000548.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Liquid chlorination equipment and enclosures

OTHER:

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).

Use one of the following methods:

- (a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

- (b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold} / 365 \text{ days} / 350 \text{ gallons per day})$

**ERC 211.3
 Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Pinal Valley (Stanfield)
 11-012
 91-000522.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	0
2.5	Various	0
3	Various	0
4	Various	7,682
6	Various	17,809
8	Various	0
10	Various	0
12	Various	0
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	190	3.16%	5.26%
3/4	1	0.00%	0.00%
1	5	20.00%	20.00%
2	1	0.00%	0.00%
3		0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	4	25.00%	0.00%
Compound 3		0.00%	0.00%
Compound 4		0.00%	0.00%
Compound 6		0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2		0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

BOOSTER PUMPS		
Horsepower	GPM	Quantity
10	120	1
15	237	1
30	475	1

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
12	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
20,000	Steel	1	Unknown
100,000	Steel	1	1976

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
5,000	Steel	1	1976

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - Pinal Valley (Stanfield)
11-012
91-000522.0000
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER:

[Redacted]

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
Use one of the following methods:

(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

(b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold} / 365 \text{ days} / 350 \text{ gallons per day})$

**ERC 251.6
Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

[Redacted]

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - White Tank
 07-128
 91-000237.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	1,610
2.5	Various	0
3	Various	0
4	Various	14,490
6	Various	170,853
8	Various	252,062
10	Various	0
12	Various	68,250
14	Various	0
16	Various	6,427
20	Various	380
24	Various	75
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	3,147	19.10%	24.66%
3/4	1,793	0.00%	0.00%
1	838	0.12%	34.84%
2	1	0.00%	0.00%
3	12	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	44	46.67%	46.67%
Compound 3	8	0.00%	0.00%
Compound 4		0.00%	0.00%
Compound 6	1	0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2		0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

BOOSTER PUMPS		
Horsepower	GPM	Quantity
5	75	1
30	550	2
50	380	3
60	1060	2
100	1500	4

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
501	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
50,000	Steel	1	1967
100,000	Steel	1	1972
374,000	Steel	2	2019, 2019
500,000	Steel	2	1982, 2021
1,000,000	Steel	2	2007, 2007

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
5,000	Steel	4	1963, 2004, 2006, 2019
10,000	Steel	1	2019

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - White Tank
 07-128
 91-00023
 0

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures
	Arroyo Seco Well #11 Arsenic Treatment Plant - coagulation/filtration filter vessels and ferric chloride for arsenic removal

OTHER: Radio controls

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
 Use one of the following methods:
 (a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold |

(b) If no historical flow data are available, use:
 $ERC = (Total\ SFR\ gallons\ sold\ (Omit\ 000\ / 365\ days\ / 350\ gallons\ per\ day))$

**ERC 274.5
 Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into acco

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Ajo
 10-003
 91-000412.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in Inches)	Material	Length (in feet)
<=2	Various	4,125
2.5	Various	0
3	Various	294
4	Various	41,451
6	Various	35,568
8	Various	3,341
10	Various	0
12	Various	0
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	617	18.48%	75.20%
3/4			
1	25	48.00%	64.00%
2			
3			
4			
Compound 1,5			
Compound 2	4	0.00%	0.00%
Compound 3			
Compound 4			
Compound 6			
Compound 8			
Turbo 2			
Turbo 3			
Turbo 4			
Turbo 6			
Turbo 8			

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

BOOSTER PUMPS		
Horsepower	GPM	Quantity
10	270	1
15	270	2

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
48	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
250,000	Steel	1	1956
500,000	Steel	1	1981

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Ajo
 10-003
 91-000412.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Liquid chlorination equipment and enclosures

OTHER:

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).

Use one of the following methods:

- (a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

- (b) If no historical flow data are available, use:
 $ERC = (Total\ SFR\ gallons\ sold\ (Omit\ 000) / 365\ days / 350\ gallons\ per\ day)$

**ERC 118.6
 Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

Company Name:
 ADEQ Public Water System No:
 Year Ended:

Arizona Water Company - Casa Grande West
 11-024
 12/31/2022

WATER COMPANY PLANT DESCRIPTION (CONTINUED)

WATER COMPANY PLANT DESCRIPTION
MAINS

Size (in inches)	Material	Length (in feet)
<=2	Various	Information Not Available 3-22-2023
2.5	Various	
3	Various	
4	Various	
6	Various	
8	Various	
10	Various	
12	Various	
14	Various	
16	Various	
20	Various	
24	Various	
36	Various	

CUSTOMERS METERS

Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	22	0%	0%
3/4	295	0%	0%
1	1	0%	0%
2			
3			
4			
Compound 1.5			
Compound 2			
Compound 3			
Compound 4			
Compound 6			
Compound 8			
Turbo 2			
Turbo 3			
Turbo 4			
Turbo 6			
Turbo 8			

SERVICE LINES

Material	Percent of system	Year installed

BOOSTER PUMPS

Horsepower	GPM	Quantity
10	unmetered	2

FIRE HYDRANTS

Type	Quantity
Standard *	0
Other	

STORAGE TANKS

Capacity (gallons)	Material	Quantity	Year installed
125,100	Bolted Steel	1	2014

PRESSURE/BLADDER TANKS

Capacity (gallons)	Material	Quantity	Year installed
5,000	Steel	1	2014

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
Year Ended:

Arizona Water Company - Casa Grande West
11-024
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	1. Well # 2 Liquid Chlorine

OTHER:

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).

Use one of the following methods:

(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the a

(b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold} / 365 \text{ days} / 350 \text{ gallons per day})$

**ERC 227.2

Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account in

WATER COMPANY PLANT DESCRIPTION (CONTINUED)

WATER COMPANY PLANT DESCRIPTION

MAINS

Size (in inches)	Material	Length (in feet)
<=2	Various	Information Not Available 3-22-2023
2.5	Various	
3	Various	
4	Various	
6	Various	
8	Various	
10	Various	
12	Various	
14	Various	
16	Various	
20	Various	
24	Various	
36	Various	

CUSTOMERS METERS

Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	4	0%	0%
3/4	55	0%	0%
1	2	0%	0%
2	1	0%	0%
3			
4			
Compound 1.5			
Compound 2	3	0%	0%
Compound 3			
Compound 4			
Compound 6			
Compound 8			
Turbo 2			
Turbo 3			
Turbo 4			
Turbo 6			
Turbo 8			

SERVICE LINES

Material	Percent of system	Year installed

BOOSTER PUMPS

Horsepower	GPM	Quantity

FIRE HYDRANTS

Type	Quantity
Standard *	
Other	

STORAGE TANKS

Capacity (gallons)	Material	Quantity	Year installed

PRESSURE/BLADDER TANKS

Capacity (gallons)	Material	Quantity	Year installed

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
Year Ended:

Arizona Water Company - Casa Grande South
11-061
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	

OTHER:

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
Use one of the following methods:
(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the a

(b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold} / 365 \text{ days} / 350 \text{ gallons per day})$

**ERC 379.7
Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account in

Company Name:

Arizona Water Company - Pinal Valley (Coolidge Airport)
(System is leased from the City of Coolidge)

ADEQ Public Water System No:

11-707

ADWR PCC Number:

91-000523.0000

Year Ended:

12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	0
2.5	Various	0
3	Various	2,898
4	Various	0
6	Various	541
8	Various	0
10	Various	0
12	Various	3,430
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8		0%	0%
3/4		0%	0%
1	3	33%	100%
2		0%	0%
3		0%	0%
4		0%	0%
Compound 1.5		0%	0%
Compound 2	4	0%	75%
Compound 3	3	0%	33%
Compound 4		0%	3%
Compound 6		0%	0%
Compound 8		0%	0%
Turbo 2	1	0%	0%
Turbo 3		0%	0%
Turbo 4		0%	0%
Turbo 6			
Turbo 8			

SERVICE LINES		
Material	Percent of system	Year Installed
n/a	n/a	

BOOSTER PUMPS		
Horsepower	GPM	Quantity
2	50	2
10	125	1
40	750	2

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
3	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
15,000	Steel	1	1951

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
5,000	Steel	1	Unknown

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:

Arizona Water Company - Pinal Valley (Coolidge Airport)
(System is leased from the City of Coolidge)

ADEQ Public Water System No:

11-707

ADWR PCC Number:

91-000523.0000

Year Ended:

12/31/2022

[Redacted box]

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

--	--	--	--	--	--	--	--	--	--

--	--	--	--	--	--	--	--	--	--

--	--	--	--	--	--	--	--	--	--

OTHER:

[Redacted box]

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).

Use one of the following methods:

(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

(b) If no historical flow data are available, use:
ERC = (Total SFR gallons sold (Omit 000 / 365 days / 350 gallons per day)

**ERC 0
Method used: n/a

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

[Redacted box]

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Lakeside)
 09-003
 91-000365.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	38,858
2.5	Various	0
3	Various	26,041
4	Various	80,365
6	Various	242,650
8	Various	77,635
10	Various	350
12	Various	6,962
14	Various	0
16	Various	80
20	Various	80
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	4,332	1.04%	3.37%
3/4	2	0.00%	0.00%
1	90	0.00%	1.11%
2	3	0.00%	0.00%
3	1	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	22	0.00%	12.00%
Compound 3	3	0.00%	0.00%
Compound 4		0.00%	0.00%
Compound 6		0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2		0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

BOOSTER PUMPS		
Horsepower	GPM	Quantity
5	130	1
7.5	170	2
10	110 - 175	4
15	300	1
20	400	1

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
228	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
40,000	Steel	1	1985
41,000	Steel	1	1966
100,000	Steel	1	1973
350,000	Steel	2	1987, 1999
500,000	Steel	2	1972, 1992

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
2,000	Steel	1	1975
5,000	Steel	1	1990

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - Navajo (Lakeside)
09-003
91-000365.0000
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER:

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
Use one of the following methods:
(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

(b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold} / 365 \text{ days} / 350 \text{ gallons per day})$

**ERC 112.5
Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Pinetop Lakes)
 09-018
 91-000374.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	380
2.5	Various	0
3	Various	0
4	Various	30,844
6	Various	36,692
8	Various	5,921
10	Various	0
12	Various	10,829
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	1,008	0.89%	2.58%
3/4		0.00%	0.00%
1	7	0.00%	0.00%
2	5	0.00%	0.00%
3		0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	22	0.00%	0.00%
Compound 3	1	0.00%	0.00%
Compound 4	1	0.00%	0.00%
Compound 6		0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2		0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

BOOSTER PUMPS		
Horsepower	GPM	Quantity
10	175	2
15	200	1
20	275	1
25	250	2
75	500	1

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
111	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
310,000	Steel	1	1973
1,000,000	Steel	1	1985

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
4,600	Steel	1	1985
10,000	Steel	1	unknown

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - Navajo (Pinetop Lakes)
09-018
91-000374.0000
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER: Generator

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
Use one of the following methods:

- (a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

- (b) If no historical flow data are available, use:
ERC = (Total SFR gallons sold (Omit 000 / 365 days / 350 gallons per day)

**ERC 104.7
Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Overgaard)
 09-004
 91-000366.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	8,572
2.5	Various	0
3	Various	0
4	Various	118,686
6	Various	259,191
8	Various	121,076
10	Various	0
12	Various	0
14	Various	0
16	Various	260
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	4,492	0.16%	3.87%
3/4	2	0.00%	0.00%
1	21	0.00%	9.52%
2	4	0.00%	0.00%
3		0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	16	0.00%	9.52%
Compound 3		0.00%	0.00%
Compound 4		0.00%	0.00%
Compound 6	1	0.00%	100.00%
Compound 8		0.00%	0.00%
Turbo 2	1	0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES		
Material	Percent of system	Year Installed
n/a	n/a	

BOOSTER PUMPS		
Horsepower	GPM	Quantity
3	50	1
5	80	1
10	160	2

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
355	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
25,000	Steel	1	1963
100,000	Steel	2	1969, 1981
250,000	Steel	1	1986
315,000	Steel	1	2007
1,000,000	Steel	1	1990

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
120	Steel	4	2002, 2002, 2012, 2012

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Overgaard)
 09-004
 91-000366.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER:

[Redacted]

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).

Use one of the following methods:

- (a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

- (b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold (Omit 000)} / 365 \text{ days} / 350 \text{ gallons per day})$

**ERC 76.2
 Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account inc

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Forrest Towne)
 n/a
 -
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	0
2.5	Various	0
3	Various	0
4	Various	1,858
6	Various	2,302
8	Various	0
10	Various	0
12	Various	0
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	7	0.00%	0.00%
3/4		0.00%	0.00%
1		0.00%	0.00%
2		0.00%	0.00%
3		0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2		0.00%	0.00%
Compound 3		0.00%	0.00%
Compound 4		0.00%	0.00%
Compound 6		0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2		0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

BOOSTER PUMPS		
Horsepower	GPM	Quantity
5	90	1

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
0	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
2,500	Poly	1	Unknown

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
119	Steel	2	

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - Navajo (Forrest Towne)
n/a

12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	
-----------------------------	--

--	--

--	--

OTHER:

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
Use one of the following methods:

(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

(b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold} / 365 \text{ days} / 350 \text{ gallons per day})$

**ERC 92.3
Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

--

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Superstition (Miami)
 04-002
 91-000117.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	92,965
2.5	Various	0
3	Various	17,595
4	Various	71,742
6	Various	123,974
8	Various	56,460
10	Various	1,096
12	Various	22,777
14	Various	110
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	2,799	1.43%	3.57%
3/4		0.00%	0.00%
1	69	0.00%	2.90%
2		0.00%	0.00%
3	2	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	39	7.14%	26.19%
Compound 3	4	14.29%	28.57%
Compound 4	2	0.00%	0.00%
Compound 6	2	0.00%	50.00%
Compound 8		0.00%	0.00%
Turbo 2	3	0.00%	0.00%
Turbo 3	1	0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

BOOSTER PUMPS		
Horsepower	GPM	Quantity
0.5	12	1
1	55	1
1.5	58	2
2	45	4
3	80	1
7.5	250	1
10	200-290	3
30	350	1
40	500	1
60	460	3
75	350	2
100	600	2

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
163	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
15,000	Steel	1	1970
20,000	Steel	1	1960
40,000	Steel	1	1973
44,000	Steel	1	1970
100,000	Steel	2	1980, 2018
120,000	Steel	1	1956
200,000	Steel	1	1968
250,000	Steel	1	1963
500,000	Steel	2	1953, 1975
1,000,000	Steel	2	1992, Unknown

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
110	Steel	3	Unknown
500	Steel	1	Unknown
5,000	Steel	2	Unknown

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Superstition (Miami)
 04-002
 91-000117,0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER:

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
 Use one of the following methods:

- (a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

- (b) If no historical flow data are available, use:

$$ERC = (\text{Total SFR gallons sold} / 365 \text{ days} / 350 \text{ gallons per day})$$

**ERC 152.3
 Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - San Manuel
 11-020
 91-000527.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	555
2.5	Various	0
3	Various	0
4	Various	47,130
6	Various	57,602
8	Various	16,800
10	Various	4,560
12	Various	0
14	Various	1,810
16	Various	2,043
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	1,426	0.42%	3.65%
3/4		0.00%	0.00%
1	16	0.00%	25.00%
2		0.00%	0.00%
3	1	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	7	0.00%	0.00%
Compound 3	1	0.00%	0.00%
Compound 4		0.00%	0.00%
Compound 6	3	0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2		0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES		
Material	Percent of system	Year Installed
n/a	n/a	

BOOSTER PUMPS		
Horsepower	GPM	Quantity
1.5	58	1
3.5	74	1
50	1280	3
100	1500	2

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
94	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
250,000	Steel	1	1953
750,000	Steel	1	1953

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - San Manuel
11-020
91-000527.0000
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	San Manuel Arsenic Treatment Plant - coagulation/filtration filter vessels and

OTHER: Mobile base radio station

[Redacted]

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
Use one of the following methods:

- (a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

- (b) If no historical flow data are available, use:
ERC = (Total SFR gallons sold (Omit 000 / 365 days / 350 gallons per day)

**ERC 143.8
Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

[Redacted]

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Falcon Valley (Oracle / SaddleBrooke)
 11-019
 91-000526.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	7,301
2.5	Various	0
3	Various	0
4	Various	65,149
6	Various	147,025
8	Various	104,753
10	Various	0
12	Various	74,206
14	Various	150
16	Various	2,530
20	Various	0
24	Various	5,589
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	3,001	0.23%	3.40%
3/4	120	0.00%	0.00%
1	121	0.00%	3.31%
2	1	0.00%	0.00%
3	3	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	20	18.18%	13.64%
Compound 3	4	0.00%	14.29%
Compound 4		0.00%	0.00%
Compound 6	1	0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2	1	0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES		
Material	Percent of system	Year Installed
n/a	n/a	

BOOSTER PUMPS		
Horsepower	GPM	Quantity
20	350	2
40	475	2
100	600	6

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
246	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
20,000	Concrete	1	1960
21,000	Concrete	1	1969
21,000	Steel	1	1960
100,000	Steel	4	1976, 1980, 1989, 2003
130,000	Steel	1	1981
750,000	Steel	1	2011
1,000,000	Steel	1	1962

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - Falcon Valley (Oracle / SaddleBrooke)
11-019
91-000526 0000
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER: Solar panel with battery backup (2)

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
Use one of the following methods:

- (a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

- (b) If no historical flow data are available, use:
ERC = (Total SFR gallons sold (Omit 000 / 365 days / 350 gallons per day)

**ERC 148.3
Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - Winkelman
04-003
91-000118.0000
12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	725
2.5	Various	0
3	Various	1,120
4	Various	9,600
6	Various	6,360
8	Various	0
10	Various	0
12	Various	0
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	139	0.00%	3.57%
3/4		0.00%	0.00%
1	3	0.00%	0.00%
2		0.00%	0.00%
3	1	0.00%	100.00%
4		0.00%	0.00%
Compound 1 5		0.00%	0.00%
Compound 2	3	0.00%	0.00%
Compound 3		0.00%	0.00%
Compound 4	2	0.00%	0.00%
Compound 6		0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2		0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES		
Material	Percent of system	Year Installed
n/a	n/a	

BOOSTER PUMPS		
Horsepower	GPM	Quantity

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
19	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
10,000	Steel	1	1973
200,000	Steel	1	1962

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Winkelman
 04-003
 91-000118.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER:

[]
 Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
 Use one of the following methods:

- (a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

- (b) If no historical flow data are available, use:
 $ERC = (Total\ SFR\ gallons\ sold\ (Omit\ 000\ / 365\ days\ / 350\ gallons\ per\ day))$

**ERC 188.1
 Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account in

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Sedona)
 03-003
 91-000083.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (In feet)
<=2	Various	75,423
2.5	Various	0
3	Various	18,607
4	Various	161,773
6	Various	287,856
8	Various	132,682
10	Various	0
12	Various	24,003
14	Various	0
16	Various	7,726
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	5,145	3.85%	19.81%
3/4	27	0.00%	0.00%
1	867	1.04%	14.19%
2		0.00%	0.00%
3	4	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	139	15.00%	65.00%
Compound 3	8	50.00%	40.00%
Compound 4	7	28.57%	42.86%
Compound 6	3	0.00%	25.00%
Compound 8	1	0.00%	0.00%
Turbo 2	1	0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6	1	0.00%	0.00%
Turbo 8			

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

835

BOOSTER PUMPS		
Horsepower	GPM	Quantity
5	60	4
7.5	100	3
10	140	4
15	150	1
20	200	4
25	400	4
50	550	0
75	700	3

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
702	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
6,000	Steel	1	1986
100,000	Steel	1	1971
102,800	Steel	1	1985
300,000	Steel	2	1958
700,000	Steel	1	1988
1,000,000	Steel	2	1977, 1994

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
1,000	Steel	2	1973, 2007
1,550	Steel	1	1985
2,000	Steel	2	1967, 1978
5,000	Steel	2	1988, 1994

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Sedona)
 03-003
 91-000083.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures
	Well #6 Arsenic Treatment Plant - adsorptive filter vessels and granular iron based disposable media for arsenic removal
	Well 9 rapid sand filters (4)



Provide a calculation used to determine the value of one water equivalent residential connection (ERC).

Use one of the following methods:

(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

(b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold} / 365 \text{ days} / 350 \text{ gallons per day})$

**ERC 277.2
 Method used: (a)

**ERC Calculation:

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Valley Vista)
 13-114
 91-000663.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	458
2.5	Various	0
3	Various	0
4	Various	2,984
6	Various	11,142
8	Various	11,387
10	Various	0
12	Various	4,574
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	624	1.30%	13.17%
3/4	5	0.00%	0.00%
1	160	0.00%	0.65%
2		0.00%	0.00%
3		0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	29	10.34%	24.14%
Compound 3	1	100.00%	0.00%
Compound 4	2	0.00%	0.00%
Compound 6		0.00%	0.00%
Compound 8	1	0.00%	0.00%
Turbo 2		0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES			
Material	Percent of system	Year Installed	
n/a	n/a		

BOOSTER PUMPS		
Horsepower	GPM	Quantity
7.5	66	1
10	120	1
20	55	1
30	500	1

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
82	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
150,000	Steel	1	1984
175,000	Steel	1	2007
250,000	Steel	1	1998

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
1,100	Steel	1	1998
5,000	Steel	2	1962, 1964

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Valley Vista)
 13-114
 91-000663.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures
	Sedona Golf Resort Arsenic Treatment Plant-adsorptive filter vessels and granular iron based disposable media for arsenic removal
STRUCTURES:	Buildings and enclosures associated with water treatment, wells, booster stations

OTHER:



Provide a calculation used to determine the value of one water equivalent residential connection (ERC).

Use one of the following methods:

(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

(b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold} / 365 \text{ days} / 350 \text{ gallons per day})$

**ERC 279.7
 Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account indus

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - Verde Valley (Pinewood)
03-002
91-000082.0000
12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	5,555
2.5	Various	0
3	Various	1,153
4	Various	70,575
6	Various	90,422
8	Various	6,056
10	Various	560
12	Various	0
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	2,976	1.38%	51.34%
3/4	3	0.00%	0.00%
1	11	0.00%	9.09%
2		0.00%	0.00%
3	1	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	5	40.00%	20.00%
Compound 3		0.00%	0.00%
Compound 4		0.00%	0.00%
Compound 6		0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2		0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES		
Material	Percent of system	Year Installed
n/a	n/a	

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
109	

BOOSTER PUMPS		
Horsepower	GPM	Quantity
2	30	2
10		0
15	2@260 2@150	4
20	200	2

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
40,000	Steel	1	1958
100,000	Steel	2	1969, 1969
500,000	Steel	2	1976, 1988

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
116	Steel	2	2016, 2016

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - Verde Valley (Pinewood)
03-002
91-000082.0000
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER:

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).

Use one of the following methods:

(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

(b) If no historical flow data are available, use:
 $ERC = (\text{Total SFR gallons sold} / 365 \text{ days} / 350 \text{ gallons per day})$

**ERC 75
Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account in

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Rimrock)
 13-046
 91-000635.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (In inches)	Material	Length (In feet)
<=2	Various	20,728
2.5	Various	0
3	Various	1,350
4	Various	61,310
6	Various	60,718
8	Various	14,507
10	Various	0
12	Various	6,462
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	1,324	3.02%	21.30%
3/4	21	0.00%	0.00%
1	12	0.00%	16.67%
2		0.00%	0.00%
3	1	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5		0.00%	0.00%
Compound 2	4	0.00%	25.00%
Compound 3		0.00%	0.00%
Compound 4		0.00%	0.00%
Compound 6		0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2	1	0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES		
Material	Percent of system	Year Installed
n/a	n/a	

BOOSTER PUMPS		
Horsepower	GPM	Quantity
5	25	2
10	400 VFD	2
15	600 VFD	3

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
76	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
100,000	Steel	1	1972
160,000	Steel	1	1985
200,000	Steel	1	1995

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
150	Steel	1	2007
1,350	Steel	1	1998
3,000	Steel	1	1964

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Rimrock)
 13-046
 91-000635.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures
	Well #5 Arsenic Treatment Plant - adsorptive filter vessels and granular iron based disposable media for arsenic removal



Provide a calculation used to determine the value of one water equivalent residential connection (ERC).

Use one of the following methods:

(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

(b) If no historical flow data are available, use:
 $ERC = \frac{\text{Total SFR gallons sold (Omit 000)}}{365 \text{ days} / 350 \text{ gallons per day}}$

**ERC 145.7
 Method used: (a)

**ERC Calculation:

Company Name:
 ADEQ Public Water System No:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Superstition (Superior)
 11-021
 91-000528.0000
 12/31/2022

WATER COMPANY PLANT DESCRIPTION

MAINS		
Size (in inches)	Material	Length (in feet)
<=2	Various	16,628
2.5	Various	0
3	Various	3,182
4	Various	33,967
6	Various	48,356
8	Various	28,186
10	Various	0
12	Various	101,504
14	Various	0
16	Various	0
20	Various	0
24	Various	0
36	Various	0

CUSTOMERS METERS			
Size (in inches)	Quantity	Percent over 1,000,000 gallons	Percent over 10 years old
5/8	1,301	1.54%	3.00%
3/4	7	0.00%	0.00%
1	16	6.25%	0.00%
2	1	0.00%	0.00%
3	3	0.00%	0.00%
4		0.00%	0.00%
Compound 1.5	1	0.00%	0.00%
Compound 2	18	0.00%	26.32%
Compound 3	2	0.00%	0.00%
Compound 4		0.00%	0.00%
Compound 6		0.00%	0.00%
Compound 8		0.00%	0.00%
Turbo 2		0.00%	0.00%
Turbo 3		0.00%	0.00%
Turbo 4		0.00%	0.00%
Turbo 6			
Turbo 8			

SERVICE LINES		
Material	Percent of system	Year Installed
n/a	n/a	

BOOSTER PUMPS		
Horsepower	GPM	Quantity
7.5	40	1
400	300	0
500	725	2
585	750	0

FIRE HYDRANTS	
Quantity Standard *	Quantity Other
92	

STORAGE TANKS			
Capacity	Material	Quantity	Year Installed
375,000	Steel	1	1973
500,000	Steel	1	1959
2,200,000	Steel	1	1920

PRESSURE / BLADDER TANKS			
Capacity	Material	Quantity	Year Installed
110	Steel	2	2009, 2009

* A standard fire hydrant has two 2.5 inch hose connection nozzles with 7.5 threads per inch, and one 4.5 inch pumper connection nozzle with 4 threads per inch.

Note: If you are filing for more than one system, please provide separate data sheets for each system.

Company Name:
ADEQ Public Water System No:
ADWR PCC Number:
Year Ended:

Arizona Water Company - Superstition (Superior)
11-021
91-000528.0000
12/31/2022

WATER COMPANY PLANT DESCRIPTION (continued)

For the following three items, list the utility owned assets in each category for each system.

TREATMENT EQUIPMENT:	Chlorination equipment and enclosures

OTHER: SCADA Equipment

Provide a calculation used to determine the value of one water equivalent residential connection (ERC).
Use one of the following methods:
(a) If actual flow data are available from the preceding 12 months, divide the total annual single family residence (SFR) gallons sold by the

(b) If no historical flow data are available, use:
 $ERC = (Total\ SFR\ gallons\ sold\ (Omit\ 000) / 365\ days) / 350\ gallons\ per\ day$

**ERC 153.7
Method used: (a)

**ERC Calculation: Arizona Water is providing the requested information; however the average day water demand calculation does not take into account inc

Customer and Other Information	
Name of the System:	0
ADEQ Public Water System Number:	
ADWR PCC Number:	

Month	Number of Customers				Other Non-Residential
	Single-Family	Multi-Family	Commercial	Turf/Irrigation	
January					
February					
March					
April					
May					
June					
July					
August					
September					
October					
November					
December					

If the system has fire hydrants, what is the fire flow requirements? GPM for hrs.

Does the system have chlorination treatment?

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement?
 If yes, provide the GPCPD amount:

Is the Water Utility located in an ADWR Active Management Area (AMA)?
 If yes, which AMA?

What is the present system connection capacity (in ERCs *) using existing lines?

What is the future system connection capacity (in ERCs *) upon service area buildout?

Describe any plans and estimated completion dates for any enlargements or improvements of this system.

* an ERC is based on the calculation on the bottom of AR9 page 12.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Superstition (Apache Junction)
 11-004
 91-000519.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January		521			36
February		521			38
March	20593	675	531	203	39
April	20634	680	531	203	36
May	20681				
June	20652	673	536	203	36
July	20,720	679	539	203	35
August	20,658	676	528	204	37
September	20,683	676	524	203	38
October	20,676	677	527	203	36
November	20,694	675	532	203	36
December	20,686	672	523	203	37
If the system has fire hydrants, what is the fire flow requirement?					
Varies based on Local Fire Authority requirements		500 - 4000	GPM for	2 - 4	hrs.
Does the system have chlorination treatment?					
				yes	

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? yes
 If yes, which AMA? Phoenix AMA

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Cochise (Bisbee)
 02-001
 91-000024.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January			300		2
February			299		2
March	3084	51	300	26	2
April	3080	55	301	26	4
May	3074				
June	3083	51	305	26	1
July	3,082	50	301	26	2
August	3,087	50	301	26	2
September	3,084	51	302	26	2
October	3,070	51	299	26	2
November	3,076	51	301	26	2
December	3,069	52	299	27	2
If the system has fire hydrants, what is the fire flow requirement?			500 - 4000	GPM for	2 - 4 hrs.
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?				yes	

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GCPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Cochise (Sierra Vista)
 02-004
 91-000025.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION						
Month	Multi-Family					
January			131			3
February			133			3
March	2988	21	133	24		4
April	2992	26	132	24		4
May	3003					
June	2997	26	131	24		3
July	3,008	27	133	24		3
August	2,997	27	130	23		2
September	3,011	27	135	23		2
October	3,004	27	134	23		2
November	3,012	27	133	23		2
December	3,016	27	130	23		2
If the system has fire hydrants, what is the fire flow required? 500 - 4000 GPM for 2 - 4 hrs.						
Varies based on Local Fire Authority requirements						
Does the system have chlorination treatment? yes						

Does the Company have an ADWR Gallons Per Capita Per Day (GPCPD) requirement? no

If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

Future area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of this system? ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Pinal Valley
 11-009
 91-000521.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January	1498				117
February	1513				123
March	31260	1239	1498	632	124
April	31674	1237	1510	641	144
May	31783				
June	31997	1238	1506	639	131
July	32,252	1,244	1,503	642	143
August	32,238	1,235	1,523	636	137
September	32,315	1,245	1,510	635	133
October	32,365	1,241	1,519	640	131
November	32,401	1,236	1,517	638	129
December	32,386	1,238	1,505	641	126
If the system has fire hydrants, what is the fire flow requirement? 500 - 4000 GPM for 2 - 4 hrs.					
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment? yes					

Does the Company have an ADWR Gallons Per Capita Per Day (GPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? yes
 If yes, which AMA? Pinal AMA

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Pinal Valley (Tierra Grande)
 11-076
 91-000548.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January			11		1
February			11		2
March	302	52	11	4	1
April	303	51	11	4	1
May	304				
June	300	52	11	4	1
July	299	55	11	4	1
August	304	51	11	4	1
September	302	51	11	4	1
October	298	54	11	4	1
November	297	51	11	4	1
December	300	52	11	4	1
	301				
If the system has fire hydrants, what is the fire flow requirement?			500 - 4000	GPM for	2 - 4
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?				yes	

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? yes
 If yes, which AMA? Pinal AMA

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Pinal Valley (Stanfield)
 11-012
 91-000522.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January	28				1
February	28				1
March	165	5	28	1	1
April	170	5	28	1	1
May	167				
June	164	5	29	1	1
July	163	5	28	1	2
August	162	5	30	1	2
September	164	6	30	1	4
October	164	6	29	1	5
November	165	6	29	1	3
December	163	7	29	1	3
If the system has fire hydrants, what is the fire flow requirement? 500 - 4000 GPM for 2 - 4 hrs.					
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment? yes					

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? yes
 If yes, which AMA? Pinal AMA

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - White Tank
 07-128
 91-000237.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January		39			19
February		41			22
March	5257	1	38	68	22
April	5443	1	42	70	19
May	5488				
June	5579	1	44	75	17
July	5,615	1	43	75	17
August	5,619	1	45	75	16
September	5,623	1	46	77	15
October	5,687	1	46	76	18
November	5,664	1	53	76	19
December	5,720	1	55	76	21
If the system has fire hydrants, what is the fire flow requirement?		500 - 4000	GPM for	2 - 4	hrs.
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?				yes	

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GCPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? yes
 If yes, which AMA? Phoenix AMA

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Ajo
 10-003
 91-000412.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January			64		5
February			65		5
March	574	15	67	2	5
April	571	15	67	2	5
May	568				
June	569	15	66	2	6
July	566	15	65	2	5
August	561	13	65	2	5
September	563	13	71	2	5
October	559	13	66	2	5
November	559	13	66	2	5
December	563	15	66	2	5
If the system has fire hydrants, what is the fire flow requirement?		500 - 4000		GPM for	2 - 4
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?		yes			

hrs.

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Casa Grande West
 11-024
 91-000530.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION

Month	Multi-Family			
January				
February				
March	315			
April	319			
May	315			
June	317			
July	318			
August	319			
September	322			
October	321			
November	318			
December	319			
If the system has fire hydrants, what is the fire flow requirement? 500 - 4000 GPM for 2 - 4 hrs.				
Varies based on Local Fire Authority requirements				
Does the system have chlorination treatment? yes				

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GCPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? yes
 If yes, which AMA? Phoenix AMA

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company -Casa Grande South (South Mountain Water Co)
 11-061
 91-000545.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January			7		0
February			8		0
March	59	0	7	1	0
April	58	0	7	1	0
May	59				
June	60	0	7	1	0
July	60	0	6	1	0
August	61	0	6	1	0
September	60	0	6	1	0
October	63	0	6	1	0
November	60	0	6	1	0
December	58	0	6	1	0
If the system has fire hydrants, what is the fire flow requirement? 500 - 4000 GPM for 2 - 4 hrs.					
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment? yes					

Does the Company have an ADWR Gallons Per Capita Per Day (GPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? yes
 If yes, which AMA? Phoenix AMA

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME

Arizona Water Company - Pinal Valley (Coolidge Airport)
(System is leased from the City of Coolidge)

11-707
91-000523.0000
12/31/2022

ADEQ Public Water System Number:
ADWR PCC Number:
Year Ended:

CUSTOMER AND OTHER INFORMATION

Month	Multi-Family				
January		9			
February		9			
March		9			
April		9			
May					
June		9			
July		9			
August		9			
September		9			
October		9			
November		9			
December		9			2
If the system has fire hydrants, what is the fire flow requirement?		500 - 4000	GPM for	2 - 4	hrs.
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?			yes		

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
If yes, provide the GCPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? yes
If yes, which AMA? Pinal AMA

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of

** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Lakeside)
 09-003
 91-000365.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January		196			4
February		196			5
March	4154	26	197	27	4
April	4154	26	199	27	5
May	4148				
June	4155	26	198	28	7
July	4,174	26	196	29	7
August	4,173	26	198	29	6
September	4,186	26	200	29	8
October	4,189	26	202	29	8
November	4,171	25	198	29	6
December	4,178	25	198	29	7
If the system has fire hydrants, what is the fire flow requirement?		500 - 4000	GPM for	2 - 4	hrs.
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?			yes		

Does the Company have an ADWR Gallons Per Capita Per Day (GPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Pinetop Lakes)
 09-018
 91-000374.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January			17		0
February			17		0
March	977	37	18	10	0
April	979	37	17	10	0
May	977				
June	979	37	17	10	1
July	977	37	17	10	0
August	980	37	17	10	0
September	986	37	17	10	0
October	984	37	17	10	0
November	979	37	17	10	0
December	982	37	17	10	0
If the system has fire hydrants, what is the fire flow requirement? 500 - 4000 GPM for 2 - 4 hrs.					
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment? yes					

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GCPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Overgaard)
 09-004
 91-000366.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January			105		14
February			105		11
March	4391	2	110	1	11
April	4403	2	106	1	11
May	4406				
June	4408	2	104	1	12
July	4,417	2	102	1	11
August	4,421	2	102	1	11
September	4,428	2	102	1	12
October	4,434	2	103	1	11
November	4,419	2	103	1	11
December	4,416	2	104	1	11
If the system has fire hydrants, what is the fire flow requi		500 - 4000	GPM for	2 - 4	hrs.
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?			yes		

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Navajo (Forrest Towne)
 N/A
 12/31/2022

CUSTOMER AND OTHER INFORMATION

Month	Multi-Family			
January				
February				
March	7			
April	7			
May		7		
June	7			
July	7			
August	7			
September	7			
October	7			
November	7			
December	7			

If the system has fire hydrants, what is the fire flow requirement? n/a GPM for n/a hrs.
 Varies based on Local Fire Authority requirements
 Does the system have chlorination treatment? no

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Superstition (Miami)
 04-002
 91-000117.0000
 12/31/2022

44926

CUSTOMER AND OTHER INFORMATION						
Month	Multi-Family					
January			212			4
February			214			3
March	2662	21	212	12		4
April	2675	22	220	12		4
May	2671					
June	2672	22	213	12		7
July	2,682	22	208	12		8
August	2,687	22	208	12		6
September	2,676	22	208	12		5
October	2,672	22	209	12		4
November	2,663	22	212	12		4
December	2,663	21	215	12		5
If the system has fire hydrants, what is the fire flow requirement? 500 - 4000 GPM for 2 - 4 hrs.						
Varies based on Local Fire Authority requirements						
Does the system have chlorination treatment? yes						

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - San Manuel
 11-020
 91-000527.0000
 12/31/2022

44926

CUSTOMER AND OTHER INFORMATION

Month	Multi-Family				
January		52			1
February		52			1
March	1423	0	53	5	1
April	1424	0	54	5	2
May	1414				
June	1416	0	53	5	1
July	1,415	0	53	5	2
August	1,413	0	53	5	1
September	1,414	0	56	5	1
October	1,407	0	53	5	1
November	1,397	0	53	5	1
December	1,397	0	54	5	1
If the system has fire hydrants, what is the fire flow requirement?			500 - 4000	GPM for	2 - 4
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?				yes	

hrs.

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of

** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Falcon Valley (Oracle / SaddleBrooke)
 11-019
 91-000526.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January			103		7
February			103		7
March	3022	20	102	17	6
April	3041	20	104	17	5
May	3056				
June	3062	20	103	17	6
July	3,094	20	103	17	7
August	3,080	20	102	17	8
September	3,124	20	105	17	8
October	3,136	20	105	17	6
November	3,143	20	102	17	6
December	3,142	20	102	17	4
If the system has fire hydrants, what is the fire flow requirement?			500 - 4000	GPM for	2 - 4
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?				yes	

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? yes
 If yes, which AMA? Tucson AMA

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Winkelman
 04-003
 91-000118.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January		17			0
February		17			0
March	131	0	17	2	1
April	132	0	17	2	1
May	131				
June	129	0	17	2	0
July	129	0	17	2	0
August	128	0	17	2	0
September	128	0	17	2	0
October	127	0	17	2	0
November	127	0	17	2	0
December	128	0	16	2	0
If the system has fire hydrants, what is the fire flow requirement? 500 - 4000 GPM for 2 - 4 hrs.					
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment? yes					

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Sedona)
 03-003
 91-000083.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January	563				16
February	563				18
March	4909	448	566	124	15
April	4917	453	567	124	16
May	4911				
June	4921	449	561	124	19
July	4,919	453	568	126	19
August	4,915	445	563	124	19
September	4,922	446	563	124	18
October	4,924	450	571	126	17
November	4,931	454	563	124	15
December	4,933	444	568	125	13
If the system has fire hydrants, what is the fire flow requirement? 500 - 4000 GPM for 2 - 4 hrs.					
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment? yes					

Does the Company have an ADWR Gallons Per Capita Per Day (GPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Valley Vista)
 13-114
 91-000663.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January		38			1
February		38			1
March	740	14	38	18	2
April	738	14	38	18	2
May	740				
June	740	15	38	18	1
July	739	14	38	18	1
August	741	14	38	18	1
September	742	14	38	18	1
October	740	14	38	18	1
November	743	14	38	18	1
December	746	14	38	18	1
If the system has fire hydrants, what is the fire flow requirement? 500 - 4000 GPM for 2 - 4 hrs.					
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment? yes					

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Pinewood)
 03-002
 91-000082.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January		22			3
February		22			3
March	2969	4	21	1	3
April	2973	4	21	1	4
May	2973				
June	2982	4	22	1	4
July	2,974	4	22	1	5
August	2,980	4	22	1	5
September	2,989	4	21	1	4
October	2,984	4	20	1	3
November	2,972	4	20	1	3
December	2,971	4	21	1	2
If the system has fire hydrants, what is the fire flow requirement?		500 - 4000	GPM for	2 - 4	hrs.
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?			yes		

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Verde Valley (Rimrock)
 13-046
 91-000635.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January			22		4
February			22		4
March	1193	138	22	5	5
April	1199	140	23	5	6
May	1209				
June	1210	136	22	5	4
July	1,204	134	22	5	4
August	1,207	136	22	5	4
September	1,203	137	23	5	4
October	1,208	135	22	5	5
November	1,205	137	22	5	4
December	1,202	132	22	5	4
If the system has fire hydrants, what is the fire flow requirement?			500 - 4000	GPM for	2 - 4
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?				yes	

hrs.

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? no
 If yes, which AMA? n/a

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

COMPANY NAME
 ADEQ Public Water System Number:
 ADWR PCC Number:
 Year Ended:

Arizona Water Company - Superstition (Superior)
 11-021
 91-000528.0000
 12/31/2022

CUSTOMER AND OTHER INFORMATION					
Month	Multi-Family				
January			110		5
February			107		4
March	1210	6	107	7	3
April	1207	6	109	7	4
May	1210				
June	1216	6	109	7	3
July	1,221	6	110	7	4
August	1,218	6	111	7	3
September	1,217	6	112	7	2
October	1,214	6	113	7	4
November	1,220	6	112	7	4
December	1,220	6	112	7	6
If the system has fire hydrants, what is the fire flow requirement?		500 - 4000	GPM for	2 - 4	hrs.
Varies based on Local Fire Authority requirements					
Does the system have chlorination treatment?			yes		

Does the Company have an ADWR Gallons Per Capita Per Day (GCPCPD) requirement? no
 If yes, provide the GPCPD amount: n/a

Is the Water Utility located in an ADWR Active Management Area (AMA)? yes
 If yes, which AMA? Phoenix AMA

What is the present system connection capacity (in ERCs *) using existing lines? ** n/a

ice area buildout? ** n/a

Describe any plans and estimated completion dates for any enlargements or improvements of
 ** n/a

* an ERC is based on the calculation on the bottom of page 13

** The capacity of a water system is dependent on many water infrastructure factors including, but not limited to the sizes and capacities of: water supplies, water storage tanks, booster pump stations, transmission and distribution water mains, and pressure zone boundaries. It is not feasible or correct to calculate or estimate the present or future system connection capacity in ERC's based on the average water demand calculation in the above section. Therefore, AWC has omitted this information from its Annual Report.

Arizona Water Company
 Annual Report
 Utility Shutoffs / Disconnects
 12/31/22

Utility Shutoffs / Disconnects	
Name of the System:	0
ADEQ Public Water System Number:	
ADWR PCC Number:	

Month	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	Other
January			
February			
March			
April			
May			
June			
July			
August			
September			
October			
November			
December			
Total	0	0	0

Other (description):

Instructions: Fill out the Grey Cells with the relevant information. Input 0 or none if there is nothing recorded in that account or there is no applicable information to report.

COMPANY NAME

Arizona Water Company - Cochise (Bisbee)

W-01445A

Docket No.:

02-001

ADEQ Public Water System Number:

91-000024.0000

ADWR PCC Number:

12/31/2022

Year Ended:

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		36	
FEBRUARY		42	
MARCH		70	
APRIL		15	
MAY		72	
JUNE		62	
JULY		9	
AUGUST		48	
SEPTEMBER		32	
OCTOBER		27	
NOVEMBER		24	
DECEMBER		22	
TOTALS →	-	459	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Pinal Valley
Docket No.:	W-01445A
ADEQ Public Water System Number:	11-009
ADWR PCC Number:	91-000521.0000
Year Ended:	12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		629	
FEBRUARY		230	
MARCH		650	
APRIL		930	
MAY		558	
JUNE		873	
JULY		914	
AUGUST		367	
SEPTEMBER		906	
OCTOBER		355	
NOVEMBER		497	
DECEMBER		656	
TOTALS →	-	7,565	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Pinal Valley (Tierra Grande)
Docket No.:	W-01445A
ADEQ Public Water System Number:	11-076
ADWR PCC Number:	91-000548.0000
Year Ended:	12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		1	
FEBRUARY		10	
MARCH		5	
APRIL		9	
MAY		4	
JUNE		15	
JULY		8	
AUGUST		4	
SEPTEMBER		9	
OCTOBER		3	
NOVEMBER		5	
DECEMBER		4	
TOTALS →	-	77	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Pinal Valley (Stanfield)
Docket No.:	W-01445A
ADEQ Public Water System Number:	11-012
ADWR PCC Number:	91-000522.0000
Year Ended:	12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		1	
FEBRUARY			
MARCH		7	
APRIL		4	
MAY		9	
JUNE		2	
JULY		10	
AUGUST		1	
SEPTEMBER		7	
OCTOBER		5	
NOVEMBER		1	
DECEMBER		8	
TOTALS →	-	55	-

OTHER (description):

None

COMPANY NAME

Arizona Water Company - White Tank

Docket No.:

W-01445A

ADEQ Public Water System Number:

07-128

ADWR PCC Number:

91-000237.0000

Year Ended:

12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		205	
FEBRUARY		48	
MARCH		161	
APRIL		130	
MAY		140	
JUNE		127	
JULY		257	
AUGUST		66	
SEPTEMBER		135	
OCTOBER		58	
NOVEMBER		67	
DECEMBER		150	
TOTALS →	-	1,544	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Ajo
Docket No.:	W-01445A
ADEQ Public Water System Number:	10-003
ADWR PCC Number:	91-000412.0000
Year Ended:	12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		6	
FEBRUARY		14	
MARCH		18	
APRIL		4	
MAY		8	
JUNE		6	
JULY		23	
AUGUST		7	
SEPTEMBER		15	
OCTOBER		8	
NOVEMBER		8	
DECEMBER		13	
TOTALS →	-	130	-

OTHER (description):

None

COMPANY NAME

Arizona Water Company - Casa Grande South

Docket No.:

ADEQ Public Water System Number:

ADWR PCC Number:

Year Ended:

11-061

91-000545.0000

12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY			
FEBRUARY		2	
MARCH		1	
APRIL		1	
MAY			
JUNE		1	
JULY		3	
AUGUST			
SEPTEMBER		2	
OCTOBER		1	
NOVEMBER		-	
DECEMBER		-	
TOTALS →	-	11	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Casa Grande West
Docket No.:	11-024
ADEQ Public Water System Number:	
ADWR PCC Number:	12/31/2022
Year Ended:	

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		9	
FEBRUARY		7	
MARCH		3	
APRIL		11	
MAY		6	
JUNE		27	
JULY		16	
AUGUST		1	
SEPTEMBER		1	
OCTOBER		11	
NOVEMBER		3	
DECEMBER		7	
TOTALS →	-	102	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Pinal Valley (Coolidge Airport)
Docket No.:	W-01445A
ADEQ Public Water System Number:	(System is leased from the City of Coolidge)
ADWR PCC Number:	11-707
Year Ended:	91-000523.0000 12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice	OTHER
JANUARY		-	
FEBRUARY		-	
MARCH		-	
APRIL		-	
MAY		-	
JUNE		-	
JULY		-	
AUGUST		-	
SEPTEMBER		-	
OCTOBER		-	
NOVEMBER		-	
DECEMBER		-	
TOTALS →	-	-	-

OTHER (description):

None

COMPANY NAME

Arizona Water Company - Navajo (Lakeside)

Docket No.:

W-01445A

ADEQ Public Water System Number:

09-003

ADWR PCC Number:

91-000365.0000

Year Ended:

12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		3	
FEBRUARY		24	
MARCH		15	
APRIL		25	
MAY		9	
JUNE		22	
JULY		12	
AUGUST		13	
SEPTEMBER		36	
OCTOBER		15	
NOVEMBER		15	
DECEMBER		16	
TOTALS →	-	205	-

OTHER (description):

None

COMPANY NAME

'Arizona Water Company - Navajo (Pinetop Lakes)

Docket No.:

W-01445A

ADEQ Public Water System Number:

09-018

ADWR PCC Number:

91-000374.0000

Year Ended:

12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		-	
FEBRUARY		-	
MARCH		-	
APRIL		1	
MAY		-	
JUNE		-	
JULY		-	
AUGUST		1	
SEPTEMBER		1	
OCTOBER		-	
NOVEMBER		1	
DECEMBER		1	
TOTALS →	-	5	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Navajo (Overgaard including Forrest Towne)	W-01445A
Docket No.:		09-004
ADEQ Public Water System Number:		91-000366.0000
ADWR PCC Number:		12/31/2022
Year Ended:		

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		5	
FEBRUARY		8	
MARCH		5	
APRIL		2	
MAY		4	
JUNE		14	
JULY		13	
AUGUST		5	
SEPTEMBER		8	
OCTOBER		5	
NOVEMBER		5	
DECEMBER		10	
TOTALS →	-	84	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Superstition (Miami)
Docket No.:	W-01445A
ADEQ Public Water System Number:	04-002
ADWR PCC Number:	91-000117.0000
Year Ended:	12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		61	
FEBRUARY		50	
MARCH		42	
APRIL		126	
MAY		18	
JUNE		70	
JULY		94	
AUGUST		73	
SEPTEMBER		42	
OCTOBER		59	
NOVEMBER		27	
DECEMBER		59	
TOTALS →	-	721	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - San Manuel
Docket No.:	W-01445A
ADEQ Public Water System Number:	11-020
ADWR PCC Number:	91-000527.0000
Year Ended:	12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		26	
FEBRUARY		20	
MARCH		28	
APRIL		37	
MAY		26	
JUNE		26	
JULY		33	
AUGUST		20	
SEPTEMBER		37	
OCTOBER		6	
NOVEMBER		18	
DECEMBER		38	
TOTALS →	-	315	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Falcon Valley (Oracle / SaddleBrooke)
Docket No.:	W-01445A
ADEQ Public Water System Number:	11-019
ADWR PCC Number:	91-000526.0000
Year Ended:	12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		20	
FEBRUARY		9	
MARCH		18	
APRIL		28	
MAY		25	
JUNE		32	
JULY		37	
AUGUST		16	
SEPTEMBER		37	
OCTOBER		9	
NOVEMBER		13	
DECEMBER		13	
TOTALS →	-	257	-

OTHER (description):

None

COMPANY NAME

Arizona Water Company - Winkelman

Docket No.:

W-01445A

ADEQ Public Water System Number:

04-003

ADWR PCC Number:

91-000118.0000

Year Ended:

12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		4	
FEBRUARY		3	
MARCH		2	
APRIL		7	
MAY		1	
JUNE		6	
JULY		3	
AUGUST		1	
SEPTEMBER		2	
OCTOBER		1	
NOVEMBER		1	
DECEMBER		2	
TOTALS →	-	33	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Verde Valley (Sedona)
Docket No.:	W-01445A
ADEQ Public Water System Number:	03-003
ADWR PCC Number:	91-000083.0000
Year Ended:	12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY			
FEBRUARY		3	
MARCH		16	
APRIL		19	
MAY		6	
JUNE		19	
JULY		19	
AUGUST		9	
SEPTEMBER		27	
OCTOBER		5	
NOVEMBER		15	
DECEMBER		13	
TOTALS →	-	151	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Verde Valley (Valley Vista)
Docket No.:	W-01445A
ADEQ Public Water System Number:	13-114
ADWR PCC Number:	91-000663.0000
Year Ended:	12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		2	
FEBRUARY		1	
MARCH		2	
APRIL		2	
MAY		2	
JUNE		1	
JULY		2	
AUGUST		1	
SEPTEMBER		1	
OCTOBER		-	
NOVEMBER		-	
DECEMBER		-	
TOTALS →	-	14	-

OTHER (description):

None

COMPANY NAME	Arizona Water Company - Verde Valley (Pinewood)
Docket No.:	W-01445A
ADEQ Public Water System Number:	03-002
ADWR PCC Number:	91-000082.0000
Year Ended:	12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		3	
FEBRUARY		2	
MARCH		4	
APRIL		8	
MAY		4	
JUNE		4	
JULY		3	
AUGUST		1	
SEPTEMBER		8	
OCTOBER		4	
NOVEMBER		3	
DECEMBER		3	
TOTALS →	-	47	-

OTHER (description):

None

COMPANY NAME

Arizona Water Company - Verde Valley (Rimrock)

Docket No.:

W-01445A

ADEQ Public Water System Number:

13-046

ADWR PCC Number:

91-000635.0000

Year Ended:

12/31/2022

UTILITY SHUTOFFS / DISCONNECTS

MONTH	Termination without Notice R14-2-410.B	Termination with Notice R14-2-410.C	OTHER
JANUARY		3	
FEBRUARY			
MARCH		13	
APRIL		8	
MAY		17	
JUNE		7	
JULY		20	
AUGUST		3	
SEPTEMBER		18	
OCTOBER		4	
NOVEMBER		15	
DECEMBER		4	
TOTALS →	-	112	-

OTHER (description):

None

Property Taxes	
Amount of actual property taxes paid during Calendar Year 2022 was	\$3,135,520

If no property taxes paid, explain why.

Instructions: Fill out the Grey Cells with the relevant information. Input 0 or none if there is nothing recorded in that account or there is no applicable information to report.

Verification and Sworn Statement (Taxes)

Verification: State of Arizona I, the undersigned of the
(state name)

County of (county name): Maricopa
Name (owner or official) title: Kevin Rogers, Vice President and Treasurer
Company name: Arizona Water Company

DO SAY THAT THIS ANNUAL UTILITY PROPERTY TAX AND SALES TAX REPORT TO THE ARIZONA CORPORATION COMMISSION.

FOR THE YEAR ENDING: 12/31/22


HAS BEEN PREPARED UNDER MY DIRECTION, FROM THE ORIGINAL BOOKS, PAPERS AND RECORDS OF SAID UTILITY; THAT I HAVE CAREFULLY EXAMINED THE SAME, AND DECLARE THE SAME TO BE A COMPLETE AND CORRECT STATEMENT OF BUSINESS AND AFFAIRS OF SAID UTILITY FOR THE PERIOD COVERED BY THIS REPORT IN RESPECT TO EACH AND EVERY MATTER AND THING SET FORTH, TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

Sworn Statement: I HEREBY ATTEST THAT ALL PROPERTY TAXES FOR SAID COMPANY ARE CURRENT AND PAID IN FULL.

I HEREBY ATTEST THAT ALL SALES TAXES FOR SAID COMPANY ARE CURRENT AND PAID IN FULL.

Kevin Rogers
signature of owner/official
602-240-6860
telephone no.

SUBSCRIBED AND SWORN TO BEFORE ME A NOTARY PUBLIC
IN AND FOR THE COUNTY Maricopa
(county name)
THIS 14th DAY OF April 2023
(month) and (year)
MY COMMISSION EXPIRES 6/21/2025
(date)



Jackie R. Craig
(signature of notary public)

Verification and Sworn Statement

Verification:

State of Arizona I, the undersigned of the
(state name)

County of (county name): Maricopa
Name (owner or official) title: Kevin Rogers, Vice President and Treasurer
Company name: Arizona Water Company

DO SAY THAT THIS ANNUAL UTILITY PROPERTY TAX AND SALES TAX REPORT TO THE ARIZONA CORPORATION COMMISSION.

FOR THE YEAR ENDING: 12/31/22


HAS BEEN PREPARED UNDER MY DIRECTION, FROM THE ORIGINAL BOOKS, PAPERS AND RECORDS OF SAID UTILITY; THAT I HAVE CAREFULLY EXAMINED THE SAME, AND DECLARE THE SAME TO BE A COMPLETE AND CORRECT STATEMENT OF BUSINESS AND AFFAIRS OF SAID UTILITY FOR THE PERIOD COVERED BY THIS REPORT IN RESPECT TO EACH AND EVERY MATTER AND THING SET FORTH, TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

Sworn Statement: IN ACCORDANCE WITH THE REQUIREMENTS OF TITLE 40, ARTICLE 8, SECTION 40-401, ARIZONA REVISED STATUTES, IT IS HEREIN REPORTED THAT THE GROSS OPERATING REVENUE OF SAID UTILITY DERIVED FROM ARIZONA INTRASTATE UTILITY OPERATIONS DURING THE CALENDAR YEAR WAS:

Arizona Intrastate Gross Operating Revenues Only (\$) \$94,125,300
(The amount in the box above includes \$8,358,412 in sales taxes billed or collected)

Kevin Rogers
signature of owner/official
602-240-6860
telephone no.

SUBSCRIBED AND SWORN TO BEFORE ME A NOTARY PUBLIC
IN AND FOR THE COUNTY Maricopa
(county name)
THIS 14th DAY OF April 2023
(month) and (year)
MY COMMISSION EXPIRES 6/21/2025
(date)



Jackie R. Craig
(signature of notary public)

Verification and Sworn Statement (Residential Revenue)

Verification:

State of Arizona I, the undersigned of the
(state name)

County of (county name): Maricopa
Name (owner or official) title: Kevin Rogers, Vice President and Treasurer
Company name: Arizona Water Company

DO SAY THAT THIS ANNUAL UTILITY PROPERTY TAX AND SALES TAX REPORT TO THE ARIZONA CORPORATION COMMISSION.

FOR THE YEAR ENDING: 12/31/22

HAS BEEN PREPARED UNDER MY DIRECTION, FROM THE ORIGINAL BOOKS, PAPERS AND RECORDS OF SAID UTILITY; THAT I HAVE CAREFULLY EXAMINED THE SAME, AND DECLARE THE SAME TO BE A COMPLETE AND CORRECT STATEMENT OF BUSINESS AND AFFAIRS OF SAID UTILITY FOR THE PERIOD COVERED BY THIS REPORT IN RESPECT TO EACH AND EVERY MATTER AND THING SET FORTH, TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

Sworn Statement:

IN ACCORDANCE WITH THE REQUIREMENTS OF TITLE 40, ARTICLE 8, SECTION 40-401, ARIZONA REVISED STATUTES, IT IS HEREIN REPORTED THAT THE GROSS OPERATING REVENUE OF SAID UTILITY DERIVED FROM ARIZONA INTRASTATE UTILITY OPERATIONS RECEIVED FROM RESIDENTIAL CUSTOMERS DURING THE CALENDAR YEAR WAS:

Arizona Intrastate Gross Operating Revenues Only (\$)

\$64,650,642

(The amount in the box above includes

\$5,741,036 in sales taxes
billed or collected)

Kevin Rogers
signature of owner/official

602-240-6860
telephone no.

SUBSCRIBED AND SWORN TO BEFORE ME A NOTARY PUBLIC
IN AND FOR THE COUNTY


Maricopa
(county name)

THIS 14th

DAY OF April 2023
(month) and (year)

MY COMMISSION EXPIRES

6/21/2025
(date)



Jackie R. Craig
(signature of notary public)

Gross-up Sharing Method for Income Tax Statement of Certification

Verification:

State of Arizona I, the undersigned of the
(state name)

County of (county name): Maricopa
Name (owner or official) title: Kevin Rogers, Vice President and Treasurer
Company name: Arizona Water Company

FOR THE YEAR ENDING: 12/31/22

Sworn Statement:


IN ACCORDANCE WITH THE REQUIREMENTS OF DECISION NO. 77084, BECAUSE THE UTILITY REQUIRES THE GROSS UP OF ADVANCES AND CONTRIBUTIONS, I HEREBY STATE THAT THE UTILITY HAS NOT INCURRED NOR IS EXPECTED TO INCUR A NET INCREASE IN CURRENT INCOME TAX EXPENSE OR A DECREASE IN DEFERRED TAX ASSET FOR A CARRY FORWARD ACCORDING TO GAAP IN AN AMOUNT EQUAL TO OR GREATER THAN THE AMOUNT OF THE REQUIRED GROSS UP PAID BY DEVELOPERS IN THE PERIOD COVERED BY THIS ANNUAL REPORT.

Kevin Rogers
signature of owner/official
602-240-6860
telephone no.

SUBSCRIBED AND SWORN TO BEFORE ME A NOTARY PUBLIC
IN AND FOR THE COUNTY Maricopa
(county name)

THIS 14th DAY OF April 2023
(month) and (year)

MY COMMISSION EXPIRES 6/21/2025
(date)



Jackie R. Craig
(signature of notary public)