

ORIGINAL

1 from the effective date of the Commission's decision.

2 25. Anway is in compliance with the rules and regulations of ADEQ and is delivering
3 water that meets the quality standards of the Safe Drinking Water Act.
4

5 CONCLUSIONS OF LAW

6 1. Anway is a public service corporation within the meaning of Article XV of the
7 Arizona Corporation Commission and A.R.S. Sections 40-250, 40-251, 40-301, 40-302 and 40-303.

8 2. The Commission has jurisdiction over Anway and of the subject matter of the
9 applications.

10 3. Notice of the applications was provided in the manner prescribed by law.

11 4. The rates and charges authorized hereafter are just and reasonable and should be
12 approved without a hearing.

13 5. The Company's financing application should be denied.

14 ORDER

15 IT IS THEREFORE ORDERED that Anway Manville Water Company, LLC shall file on or
16 before January 7, 2000, the following schedule of rates and charges:

17 Eff: 1-1-00

18 MONTHLY USAGE CHARGES

19	5/8" x 3/4" Meter	\$30.00
	3/4" Meter	46.00
	1" Meter	49.00
20	1 1/2" Meter	87.00
	2" Meter	180.00
21	3" Meter	145.00
	4" Meter	200.00
22	6" Meter	275.00

23 Charge per 1,000 Gallons:

24	Usage from 1 - 12,000 gallons	\$3.50
	Usage over 12,000 gallons	\$5.75

25
26 ...
27 ...
28 ...

APPROVED FOR FILING
DECISION NO. 62240

ORIGINAL

1	<u>SERVICE LINE AND METER</u>	
	<u>INSTALLATION CHARGES</u>	
2	(Refundable Pursuant to A.A.C. R14-2-	
	405(B))	
3	5/8" x 3/4" Meter	\$400.00
	3/4" Meter	440.00
4	1" Meter	500.00
	1 1/2" Meter	715.00
5	2" Meter Turbo	1,170.00
	3" Meter Turbo	1,585.00
6	4" Meter Turbo	2,540.00
	6" Meter Turbo	4,815.00

7	<u>SERVICE CHARGES</u>	
8	Establishment	\$25.00
	Establishment (After Hours)	30.00
9	Reconnection (Delinquent)	25.00
	Meter Test (If Correct)	40.00
10	Deposit	0
	Deposit Interest	0
11	Re-Establishment (Within 12 Months)	*
	NSF Check	15.00
12	Deferred Payment (Per Month)	1.5%
	Meter Re-Read (If Correct)	15.00

13 * Months off system times the minimum (R14-2-403.D)

14
15 IT IS FURTHER ORDERED the aforementioned rates shall become effective as of January 1,
16 2000.

17 IT IS FURTHER ORDERED that Anway Manville Water Company, L.L.C. shall notify its
18 customers of the rates and charges authorized herein and the effective date of same by means of an
19 insert in its next regular monthly billing.

20 IT IS FURTHER ORDERED that Anway Manville Water Company, L.L.C. shall file with the
21 Commission within 60 days from the effective date of this Decision a copy of the notice it sends to its
22 customers of the new rates and charges.

23 IT IS FURTHER ORDERED that Anway Manville Water Company, L.L.C., is hereby denied
24 its request for approval of \$117,200 of long-term debt.

25 IT IS FURTHER ORDERED that Anway Manville Water Company, L.L.C. shall reclassify
26 the \$117,200 loan as paid-in-capital.

27 IT IS FURTHER ORDERED that Anway Manville Water Company, L.L.C., shall file an
28 affidavit with the Commission, within 30 days from the effective date of this Decision, that the

APPROVED FOR FILING

DECISION NO. 62240
DECISION #: _____

NEW APPLICATION

ORIGINAL

RECEIVED
AZ CORP COMMISSION

Company Name: Anway Manville LLC Water Company Page 1 of 2

Jul 24 11 14 AM '98

CROSS-CONNECTION OR BACKFLOW TARIFF

DOCUMENT CONTROL

PURPOSE:

DOCKET NO. W-03233A-98-0424

The purpose of this tariff is to protect Anway Manville LLC Water Company (Company) water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code (A.A.C.) R14-2-405.B.6 and A.A.C. R18-4-115.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission (Commission) and the Arizona Department of Environmental Quality (ADEQ), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-115 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-115.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-115.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff.
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is not applicable, the customer shall be given thirty (30) days in which to comply with this notice. If the customer can show good cause as to why he cannot install the device within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

****FOR OFFICIAL USE ONLY****

Effective Date: August 22, 1998

APPROVED FOR FILING
DECISION #: <u>N/A</u>

ORIGINAL

Company Name: Anway Manville LLC Water Company Page 2 of 2

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-115.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests. The Company may also require the customer to pay for repairs to a backflow-prevention assembly.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location;
 - c. date(s) of tests(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
- 7A. In the event the backflow-prevention assembly does not function properly or fails any test, and a hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested before service is restored.
- 8A. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.


****FOR OFFICIAL USE ONLY****

Effective Date: August 22, 1998

APPROVED FOR FILING
DECISION #: N/A

ORIGINAL

Tariff Schedule



Utility: Anway Manville Water Company, L.L.C.
Docket No.: W-03233 A-01-0431
Phone No.: 520-623-5172

Tariff Sheet No.: 1 of 2
Decision No. 63918
Effective: August 6, 2001

CURTAILMENT PLAN FOR ANWAY MANVILLE WATER COMPANY, L.L.C.

The Company is authorized to curtail water service, to all customers, residential and commercial, within its certificated area under the following terms and conditions:

Stage 1 Exists When:

- a. The Company is able to maintain water storage in the system at 100 % of capacity and there are no known problems with its well production or water storage in the system.

Restrictions: Under Stage 1, the Company is deemed to be operating normally and no curtailment is necessary.

Notice Requirements: Under Stage 1, no notice is necessary.

Stage 2 Exists When:

- a. The Company's total storage and well production has been less than 80 % of capacity for at least 48 consecutive hours, and
- b. The Company has identified issues such as steadily declining water table, an increased draw-down threatening pump operations, and poor water production creating a reasonable belief the Company will be unable to meet anticipated water demands in the system.

Restrictions: Under Stage 2, the Company may request the customers to voluntarily employ water conservation measures to reduce water consumption by approximately 50 %. Outside watering should be limited to essential water, dividing outside watering on some uniform basis (such as even and odd days) and eliminating outside watering on weekends and holidays.

Notice Requirements: Under Stage 2, the Company is required to notify customers by delivering written notice door to door at each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such Notice shall notify the customers of the general nature of the problem and the need to conserve water.

Stage 3 Exists When:

- a. The Company's total storage and well production has been less than 50 % for at least 24 consecutive hours.
- b. The Company has identified issues such as a steadily declining water table, and increased draw down threatening pump operations creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 3, the Company shall request the customers to voluntarily employ water conservation measures to reduce daily consumption by approximately 50 %. All outside watering should be eliminated, except livestock, and indoor water conservation techniques should be employed wherever possible.

APPROVED FOR FILING
DECISION #: 63918

ORIGINAL

Tariff Schedule (continued)

Utility: Anway Manville Water Company L.L.C.

Docket No.: W-03233 A-01-0431

Phone No.: 520-623-5172

Tariff Sheet No.: 2 of 2

Decision No. 63918

Effective: August 6, 2001

Notice Requirements: a. The Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the company's option, both. Such Notice shall notify the customers of the general nature of the problem and the need to conserve water.

b. Beginning with Stage 3, the Company shall post at least two signs showing curtailment stage. Signs shall be posted at the well site and at the entrance to the major subdivision served by the Company.

c. The Company shall notify the Consumer Services Section of the Utilities Division of the Commission at least 12 hours prior to entering Stage 3. In addition, the Company shall inform the Consumer Services Section of the Company's plans to correct the water shortage problem and how long the Company expects to remain in Stage 3.

Stage 4 Exists When:

- a. The Company's total storage has been less than 25 % for at least 12 consecutive hours.
- b. The Company has identified issues such as steadily declining water table, an increased draw-down threatening pump operations, and poor water production creating a reasonable belief the Company will be unable to meet anticipated water demands in the system.

Restrictions: Under Stage 4, the Company shall inform the customers of a mandatory restriction to employ water conservation measures to reduce daily consumption. All outside watering should be eliminated, except livestock, and indoor water conservation techniques should be employed wherever possible. Failure to comply will result in temporary disconnection.

Notice Requirements: a. The Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the company's option, both. Such Notice shall notify the customers of the general nature of the problem and the need to conserve water.

b. The Company shall have posted at least two signs showing curtailment stage. Signs shall be posted at the well site and at the entrance to the major subdivision served by the Company.

c. The Company shall notify the Consumer Services Section of the Utilities Division of the Commission at least 12 hours prior to entering Stage 4. In addition, the Company shall inform the Consumer Services Section of the Company's plans to correct the water shortage problem and how long the Company expects to remain in Stage 4. The Company shall immediately notify the Consumer Services Section when the State 4 restrictions are lifted.

d. Customers who fail to comply with cessation of outdoor use provisions will be given a written notice to end all outside use. Failure to comply within two (2) working days of receipt of the notice will result in temporary loss of service until an agreement can be made to end unauthorized use of outside water. To restore service, the customer shall be required to pay all authorized reconnection fees.

APPROVED FOR FILING

DECISION #: 63918