

ORIGINAL

Docket # W-02526A-09-0421
Decision 71868

MONTHLY CUSTOMER CHARGE:

5/8" X 3/4" Meter	\$ 16.00
3/4" Meter	24.00
1" Meter	40.00
1 1/2" Meter	80.00
2" Meter	128.00
3" Meter	256.00
4" Meter	400.00
6" Meter	800.00

WATERHAULING SURCHARGE:

The water hauling surcharge will be calculated by dividing the total water hauling cost incurred in a given month by the amount of water sold that month. The resulting rate per 1,000 gallons will be multiplied by the gallons used in the month the water hauling cost were incurred for each customer to arrive at the surcharge per 1000 gallons. The resulting water hauling surcharge will appear as a charge in the next month as a separate line item on the customer's bill.

COMMODITY CHARGE:

Residential

0 to 4,000 gallons (per 1,000 gallons)	\$ 15.00
4001 to 10,000 gallons	22.50
Over 10,000 gallons	29.00

Commercial

0 to 10,000 gallons (per 1,000 gallons)	22.50
Over 10,000 gallons	29.00

STANDPIPE: (PER 1,000 GALLONS) 9.00

SERVICE LINE AND METER INSTALLATION CHARGES:

(Refundable pursuant to A.A.C. R14-2-405)

	<u>Service Line</u>	<u>Meter</u>	<u>Total</u>
5/8" X 3/4" Meter	\$ 415.00	\$ 105.00	\$ 520.00
3/4" Meter	415.00	205.00	620.00
1" Meter	465.00	265.00	730.00
1 1/2" Meter	520.00	475.00	995.00
2" Turbine Meter	800.00	995.00	1,795.00
2" Compound Meter	800.00	1,840.00	2,640.00
3" Turbine Meter	1,015.00	1,620.00	2,635.00
3" Compound Meter	1,135.00	2,495.00	3,630.00
4" Turbine Meter	1,430.00	2,570.00	4,000.00
4" Compound Meter	1,610.00	3,545.00	5,155.00
6" Turbine Meter	2,150.00	4,925.00	7,075.00
6" Compound Meter	2,270.00	6,820.00	9,090.00

APPROVED FOR FILING

DECISION #: 71868

ORIGINAL

SERVICE CHARGES:

Establishment	\$ 30.00
Establishment (After Hours)	45.00
Reconnection (Delinquent)	30.00
Reconnection (Delinquent) (After Hours)	45.00
Meter Test (If Correct)	40.00
Deposit	*
Deposit Interest (Per Annum)	*
Reestablishment (Within 12 Months)	**
NSF Check	20.00
Deferred Payment (Per Month)	1.5%
Meter Re-Read (If Correct)	20.00
Late Fee (Per Month)	1.5%

FIRE SPRINKLER:

* Per Commission rule A.A. C. R-14-2-403(B)

** Number of months off system times the monthly minimum, per Commission rule A.C. R14-2-403(D)

*** 2.0% of monthly minimum for a comparable sized meter connection, but no less than \$ 10 per month. The service charge for fire sprinklers is only applicable for service lines separate and distinct from the primary water service line.

APPROVED FOR FILING
DECISION #: 71868

Company Name: Bellermont Water Company Page 1 of 2

ORIGINAL

CROSS-CONNECTION OR BACKFLOW TARIFF

PURPOSE:

The purpose of this tariff is to protect Bellermont Water Company ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-115.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-115 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-115.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-115.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff.
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is not applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the device within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

****FOR OFFICIAL USE ONLY****

Effective Date: 6.3.07

**ADMINISTRATIVELY
APPROVED FOR FILING**

Company Name: Bellefont Water Company Page 2 of 2

ORIGINAL

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-115.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location
 - c. date(s) of test(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is not applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

****FOR OFFICIAL USE ONLY****

Effective Date: 6.3.07ADMINISTRATIVELY
APPROVED FOR FILING

Utility: Bellemont Water Company
Docket Nos.: W-02526A-02-0320 & 0697
Phone No.: 928-635-2467

ORIGINAL

Tariff Sheet No.: 1 of 4
Decision No.: 65853
Effective: May 1, 2003

CURTAILMENT PLAN FOR BELLEMONT WATER COMPANY

ADEQ Public Water System #03-394

Bellemont Water Company ("Company") is authorized to curtail water service to all customers within its certificated area under the terms and conditions listed in this tariff.

This curtailment plan shall become part of the Arizona Department of Environmental Quality Emergency Operations Plan for the Company.

The Company shall notify its customers of this new tariff as part of its next regularly scheduled billing after the effective date of the tariff or no later than sixty (60) days after the effective date of the tariff.

The Company shall provide a copy of the curtailment tariff to any customer, upon request.

Stage 1 Exists When:

Company is able to maintain water storage in the system at 100 percent of capacity and there are no known problems with its well production or water storage in the system.

Restrictions: Under Stage 1, Company is deemed to be operating normally and no curtailment is necessary.

Notice Requirements: Under Stage 1, no notice is necessary.

Stage 2 Exists When:

- a. Company's water storage or well production has been less than 80 percent of capacity for at least 48 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 2, the Company may request the customers to voluntarily employ water conservation measures to reduce water consumption by approximately 50 percent. Outside watering should be limited to essential water, dividing outside watering on some uniform basis (such as even and odd days) and eliminating outside watering on weekends and holidays.

APPROVED FOR FILING
DECISION #: 65853

TARIFF SCHEDULE

Attachment CPT

Utility: Bellemont Water Company
Docket Nos.: W-02526A-02-0320 & 0697
Phone No.: 928-635-2467

Tariff Sheet No.: 2 of 4
Decision No.: 65853
Effective: May 1, 2003

ORIGINAL

Notice Requirements: Under Stage 2, the Company is required to notify customers by delivering written notice door to door at each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.

Stage 3 Exists When:

- a. Company's total water storage or well production has been less than 50 percent of capacity for at least 24 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 3, Company shall request the customers to voluntarily employ water conservation measures to reduce daily consumption by approximately 50 percent. All outside watering and Standpipe Service should be eliminated, except livestock, and indoor water conservation techniques should be employed whenever possible.


Notice Requirements:

1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such Notice shall notify the customers of the general nature of the problem and the need to conserve water.
2. Beginning with Stage 3, Company shall post at least two signs showing the curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to major subdivisions served by the Company.
3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering Stage 3.

Once Stage 3 has been reached, the Company must begin to augment the supply of water by either hauling or through an emergency interconnect with an approved water supply in an attempt to maintain the curtailment at a level no higher than Stage 3 until a permanent solution has been implemented.

Stage 4 Exists When:

- a. Company's total water storage or well production has been less than 25 percent of capacity for at least 12 consecutive hours, and



REVISED: September 18, 2002

TARIFF SCHEDULE

Attachment CPT

Utility: Bellemont Water Company
Docket Nos.: W-02526A-02-0320 & 0697
Phone No.: 928-635-2467

Tariff Sheet No.: 3 of 4
Decision No.: 65853
Effective: May 1, 2003

ORIGINAL

- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 4, Company shall inform the customers of a **mandatory** restriction to employ water conservation measures to reduce daily consumption. Failure to comply will result in customer disconnection. The following uses of water shall be prohibited:

- ◆ Irrigation of outdoor lawns, trees, shrubs, or any plant life is prohibited
- ◆ Washing of any vehicle is prohibited
- ◆ The use of water for dust control or any outdoor cleaning uses is prohibited
- ◆ The use of drip or misting systems of any kind is prohibited
- ◆ The filling of any swimming pool, spas, fountains or ornamental pools is prohibited
- ◆ Restaurant patrons shall be served water only upon request
- ◆ Any other water intensive activity is prohibited

The Company's operation of its Standpipe Service is prohibited.

Notice Requirements:

1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.
2. Company shall post at least two signs showing curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to major subdivisions served by the Company.
3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering Stage 4.

Customers who fail to comply with the above Restrictions will be given a written notice to end all outdoor use. Failure to comply within two (2) working days of receipt of the notice will result in temporary loss of service until an agreement can be made to end unauthorized use of outdoor water. To restore service, the customer shall be required to pay all authorized reconnection fees. If a customer believes he/she has been disconnected in error, the customer may contact the Commission's Consumer Services Section at 1-800-222-7000 to initiate an investigation.



REVISED: September 18, 2002

TARIFF SCHEDULE

Attachment CPT

Utility: Belmont Water Company
Docket Nos.: W-02526A-02-0320 & 0697
Phone No.: 928-635-2467

Tariff Sheet No.: 4 of 4
Decision No.: 65853
Effective: May 1, 2003

ORIGINAL

Once Stage 4 has been reached, the Company must augment the supply of water by hauling or through an emergency interconnect from an approved supply or must otherwise provide emergency drinking water for its customers until a permanent solution has been implemented.

APPROVED FOR FILING
DECISION #: 65853

REVISED: September 18, 2002