

ORIGINAL

WATER TARIFF SCHEDULE

UTILITY: **MORMON LAKE WATER CO.**
DOCKET NO: W-01472A-07-0208

DECISION NO: 70103
EFFECTIVE: JAN. 1, 2008

RECEIVED

RATES AND CHARGES

2013 NOV 15 A 9 57

AZ CORP COMMISS
DOCKET CONTROL

**CUSTOMER/MINIMUM CHARGES
PER MONTH**

**SERVICE LINE & METER
INSTALLATION CHARGES**

METER	CHARGES	GALLONS	METER	CHARGES
5/8"x 3/4"	\$ 34.50		5/8"x3/4"\$	400.00
3/4"	51.75		3/4"	400.00
1"	86.25		1"	500.00
1 1/2"	172.50		1 1/2"	715.00
2" (Turbo)	276.00		2"	1170.00
3" (Turbo)	517.50		3"	1585.00
4" (Turbo)	862.50		4"	2540.00
6" (Turbo)	1172.50		6"	4815.00

COMMODITY CHARGE

PER 1,000 GALLONS

5/8"X3/4" AND 3/4" METERS

0 gallons to 4,000 gallons	10.73
Over 4,000 gallons	12.87

ALL OTHER SIZES

0 gallons to 4,000 gallons	\$ 7.15
4,001 gallons to 7,000 gallons	10.73
Over 7,000 gallons	12.87

SERVICE CHARGES

- 1. ESTABLISHMENT \$ 50.00
- 2. ESTABLISHMENT/AFTER HOURS 60.00
- 3. RECONNECTION/DELINQUENT 60.00
- 4. NSF CHECK (R14-2-409) 25.00
- 5. METER REREAD/IF CORRECT (14-2-403.C.2) 10.00
- 6. METER TEST/IF CORRECT (R14-2-408 F.1) 45.00
- 7. DEFERRED PAYMENT (PER MONTH) 0.0%
- 8. LATE PAYMENT PENALTY (PER MONTH) ***
- 9. DEPOSIT INTEREST 6%
- 10. DEPOSIT (R14-2-403.B.7) *
- 11. RE-ESTABLISHMENT (within 12 months) **
- 12. RECONNECTION (delinquent) after hours 85.00

MONTHLY SERVICE CHARGE FOR FIRE SPRINKLERS:

4" or smaller	****
6"	****
8"	****
10"	****
Larger than 10"	****

- * Per Commission Rule A.A.C.R14-2-403(B)
- ** Number of months off system times the monthly minimum per Commission Rule A.A.C.R14-2-403(D)
- *** 1.5% of monthly unpaid balance.
- **** 1.00% of Monthly Minimum for a comparable sized meter connection, but no less than \$5.00 per month. The service charge for fire sprinklers is only applicable for service lines separate and distinct from the primary water service line.

OTHER RATES AND CHARGES APPROVED BY ORDER

IN ADDITION TO THE COLLECTION OF ITS REGULAR RATES AND CHARGES, THE COMPANY SHALL COLLECT FROM ITS CUSTOMERS THEIR PROPORTIONATE SHARE OF ANY PRIVILEGE, SALES OR USE TAX IN ACCORDANCE WITH R14-2-409.D.5.

RECEIVED

NOV 14 2013

AZ CORP COMM
Director Utilities

APPROVED FOR FILING

DECISION #: 70103

John

TARIFF SCHEDULE

Utility: Mormon Lake Water Company
Docket No.: W-01472A-02-0947
Phone No.: 928-354-2227

Tariff Sheet No.: 1 of 3
Decision No.: 66035
Effective: July 3, 2003

ORIGINAL

RECEIVED

CURTAILMENT PLAN FOR MORMON LAKE WATER COMPANY
(Template 091802)

MAY 07 2004

ADEQ Public Water System Numbers: 03-014 & 03-091

ARIZONA CORPORATION COMMISSION
DIRECTOR OF UTILITIES

Mormon Lake Water Company ("Company") is authorized to curtail water service to all customers within its certificated area under the terms and conditions listed in this tariff.

This curtailment plan shall become part of the Arizona Department of Environmental Quality Emergency Operations Plan for the Company.

The Company shall notify its customers of this new tariff as part of its next regularly scheduled billing after the effective date of the tariff or no later than sixty (60) days after the effective date of the tariff.

The Company shall provide a copy of the curtailment tariff to any customer, upon request.

Stage 1 Exists When:

Company is able to maintain water storage in the system at 100 percent of capacity and there are no known problems with its well production or water storage in the system.

Restrictions: Under Stage 1, Company is deemed to be operating normally and no curtailment is necessary.

Notice Requirements: Under Stage 1, no notice is necessary.

Stage 2 Exists When:

- a. Company's water storage or well production has been less than 80 percent of capacity for at least 48 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 2, the Company may request the customers to voluntarily employ water conservation measures to reduce water consumption by approximately 50 percent. Outside watering should be limited to essential water, dividing outside watering on some uniform basis (such as even and odd days) and eliminating outside watering on weekends and holidays.

ADMINISTRATIVELY
APPROVED FOR FILING

TARIFF SCHEDULE

ORIGINAL

Utility: Mormon Lake Water Company
Docket No.: W-01472A-02-0947
Phone No.: 928-354-2227

Tariff Sheet No.: 2 of 3
Decision No.: 66035
Effective: July 3, 2003

Notice Requirements: Under Stage 2, the Company is required to notify customers by delivering written notice door to door at each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.

Stage 3 Exists When:

- a. Company's total water storage or well production has been less than 50 percent of capacity for at least 24 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 3, Company shall request the customers to voluntarily employ water conservation measures to reduce daily consumption by approximately 50 percent. All outside watering should be eliminated, except livestock, and indoor water conservation techniques should be employed whenever possible.

Notice Requirements:

- 1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such Notice shall notify the customers of the general nature of the problem and the need to conserve water.
- 2. Beginning with Stage 3, Company shall post at least 7 signs showing the curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to major subdivisions served by the Company.
- 3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering Stage 3.

Once Stage 3 has been reached, the Company must begin to augment the supply of water by either hauling or through an emergency interconnect with an approved water supply in an attempt to maintain the curtailment at a level no higher than Stage 3 until a permanent solution has been implemented.

Stage 4 Exists When:

- a. Company's total water storage or well production has been less than 25 percent of capacity for at least 12 consecutive hours, and

ADMINISTRATIVELY
APPROVED FOR FILING

TARIFF SCHEDULE

Utility: Mormon Lake Water Company
Docket No.: W-01472A-02-0947
Phone No.: 928-354-2227

Tariff Sheet No.: 3 of 3
Decision No.: 66035
Effective: July 3, 2003

- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 4, Company shall inform the customers of a **mandatory** restriction to employ water conservation measures to reduce daily consumption. Failure to comply will result in customer disconnection. The following uses of water shall be prohibited:

- ◆ Irrigation of outdoor lawns, trees, shrubs, or any plant life is prohibited
- ◆ Washing of any vehicle is prohibited
- ◆ The use of water for dust control or any outdoor cleaning uses is prohibited
- ◆ The use of drip or misting systems of any kind is prohibited
- ◆ The filling of any swimming pool, spas, fountains or ornamental pools is prohibited
- ◆ Restaurant patrons shall be served water only upon request
- ◆ Any other water intensive activity is prohibited

Notice Requirements:

1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.
2. Company shall post at least 7 signs showing curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to major subdivisions served by the Company.
3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering Stage 4.

Customers who fail to comply with the above restrictions will be given a written notice to end all outdoor use. Failure to comply within two (2) working days of receipt of the notice will result in temporary loss of service until an agreement can be made to end unauthorized use of outdoor water. To restore service, the customer shall be required to pay all authorized reconnection fees. If a customer believes he/she has been disconnected in error, the customer may contact the Commission's Consumer Services Section at 1-800-222-7000 to initiate an investigation.

Once Stage 4 has been reached, the Company must augment the supply of water by hauling or through an emergency interconnect from an approved supply or must otherwise provide emergency drinking water for its customers until a permanent solution has been implemented.

ADMINISTRATIVELY
APPROVED FOR FILING

Company Name: MORMON LAKE WATER COMPANY, INC.

Page 2 of 2

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-115.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests. The Company may also require the customer to pay for repairs to a backflow-prevention assembly.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
- a. assembly identification number and description;
 - b. location;
 - c. date(s) of test(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
- 7A. In the event the backflow-prevention assembly does not function properly or fails any test, and a hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested before service is restored.
- 7B. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is not applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or disfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

**** FOR OFFICIAL USE ONLY ****

Effective Date: January 11, 1997

