

**PUBLIC NOTICE**

**SUNRISE WATER CO.'S TARIFF**  
**AT VARIANCE WITH ARIZONA ADMINISTRATIVE CODE R14-2-**  
**410.A.2 AND TARIFF FOR SHARING CUSTOMER WATER**  
**CONSUMPTION INFORMATION WITH THE CITY OF PEORIA**  
**(DOCKET NO. W-02069A-13-0328)**


**Summary:**

On December 17, 2013, in this docket, the Arizona Corporation Commission ("Commission") issued Decision No. 74241 granting a variance from Arizona Corporation Commission Rule A.A.C. R14-2-410.A.2 for the limited purpose of entering into a Water Services Termination Agreement with the City of Peoria, a municipal provider of wastewater service, for common customers purchasing water from Sunrise Water Co. and wastewater service from the City of Peoria. The purpose of this Tariff, and the authorized variance from A.A.C. R14-2-410.A.2, is to assist the City of Peoria in collecting delinquent payments for wastewater utility service provided to common customers of Sunrise Water Co. The City of Peoria provides municipal wastewater service to many of our water customers. The tariff authorizes Sunrise Water Co. to shut off water service to delinquent Peoria wastewater customers until the delinquent bills are paid.

AND

A Tariff authorizes Sunrise Water Co. to share water consumption information of individual customers with City of Peoria, a municipal provider of wastewater service for common customers purchasing water from Sunrise Water Co. and wastewater from City of Peoria. The purpose of this Tariff, and the authorized provision of customer water consumption information, is to assist the City of Peoria in billing for wastewater utility service. The City of Peoria agrees that it is only authorized to use such water consumption information for purpose of wastewater services billing and is not authorized to disclose such information to any other party except as may be required by law.

The above Tariffs are available upon request or may be examined at our office located at 9098 W. Pinnacle Peak Road Peoria, Arizona 85383 (second floor). If you have any questions please call our office at 623-972-6133.



Company: <b>SUNRISE WATER CO.</b>	Decision No.: <b>74241</b>
<b>Docket No. W-02069A-13-0328</b>	
Phone: 623-972-6133	Effective Date: March 1, 2014

**WATER SERVICE TERMINATION TARIFF**

Sunrise Water Co. ("Company") has been granted a variance from Arizona Corporation Commission Rule A.A.C. R14-2-410.A.2 for the limited purpose of entering into a Water Service Termination Agreement ("Agreement") with the City of Peoria, a municipal provider of wastewater service, for the common customers purchasing water from the Company and wastewater from the City. The purpose of this tariff, and the authorized variance from A.A.C.R14-2-410.A.2, is to assist the City in collecting delinquent payments for wastewater utility service provided to common customers of the Company.

As per the Agreement, the Company is authorized to charge the City of Peoria the following fees:

**Fee Schedule:**

**Disconnect Fee** **\$80.00**  
(Turn-off and Turn-on service included)

**Disconnect Cancellation Fee** **\$80.00**  
(When City cancels a termination request after noon  
(12pm) on the date service is scheduled to be shut off)

**Monthly Lost Revenue Fee** **\$61.56**  
(Based on Company rate effective January 1, 2011 using  
Average revenue from ¾ to 1" metered residential customers  
Including all applicable combined state and federal tax rate of 39%)

**Terms and Conditions**

The company shall comply with the terms and conditions of the Agreement.  
The Agreement with the City is attached to and incorporated into this tariff.

APPROVED FOR FILING  
DECISION #: 74241

Company: **SUNRISE WATER CO.**

Decision No.: **74241**

Docket No. **W-02069A-13-0328**

Phone: **623-972-6133**

Effective Date: **March 1, 2014**

## **CUSTOMER WATER CONSUMPTION INFORMATION SHARING TARIFF**

Sunrise Water Co. ("Company") is authorized to share water consumption information of individual customers with the City of Peoria ("the City"), a municipal provider of wastewater services for a common customers purchasing water from the Company and wastewater from the City. The purpose of this Tariff, and the authorized provision of customer water consumption information, is to assist the City in billing for wastewater utility service. The City agrees that it is only authorized to use such water consumption information for purpose of wastewater services billing and is not authorized to disclose such information to any other party except as may be required by law.

Company entered into an Agreement with the City for providing individual water consumption data, in a form materially similar to the standard agreement. The Agreement was subject to Arizona Corporation Commission ("Commission") review as set forth in Section 3 of the Agreement.

Company shall notify all water utility customers affected by the Agreement between the Company and the City pursuant to this Tariff, by means of a billing insert during the first billing cycle immediately after said tariff is approved.

APPROVED FOR FILING

DECISION #: 74241

SUNRISE WATER CO.  
9098 W. Pinnacle Peak Rd.  
Peoria, Arizona 85383  
Filed by: J D. Campbell  
Title: President

Tariff Sheet No. 1

ACC Decision No. 71445  
Filed: January 25, 2010  
Effective: For all service rendered on and after  
January 1, 2010

## GENERAL WATER SERVICE

### Availability

Available for all metered residential, commercial, and public authority customers served by the Company.

### Monthly Usage Charge:

¾" Meter	\$17.00
1" Meter	28.33
1 ½" Meter	56.65
2" Meter	90.64
3" Hydrant Meter	181.28
4" Meter	308.25
6" Meter	566.50
8" Meter	906.40
Coin-operated Standpipe	N/A

### COMMODITY RATES (PER 1,000 Gallons):

#### ¾" Meter

From 1 to 4,000 Gallons	\$1.75
From 4,001 to 13,000 Gallons	2.50
Over 13,000 Gallons	3.15

#### 1" Meter

From 1 to 27,000 Gallons	\$2.50
Over 27,000 Gallons	3.15

#### 1 ½" Meter

From 1 to 35,000 Gallons	\$2.50
Over 35,000 Gallons	3.15

#### 2" Meter and Larger

From 1 to 65,000 Gallons	\$2.50
Over 65,000 Gallons	3.15

#### 3" Hydrant Meter

All Usage	\$2.50
-----------	--------

#### Coin-operated Standpipe

All Usage	\$2.50
-----------	--------

### Terms and Conditions:

Water service under this Schedule is for the exclusive use of the Customer and water shall not be resold or provided to others.

In addition to the collection of regular rates, the Company will collect from its Customer for a proportionate share of any privilege, sales, use and franchise tax, per Commission Rule A.A.C. R14-2-409(D)(5).

APPROVED FOR FILING

DECISION #: 71445

**ORIGINAL**

SUNRISE WATER CO.  
9098 W. Pinnacle Peak Rd.  
Peoria, Arizona 85383  
Filed by: J D. Campbell:  
Title: President

Tariff Sheet No. 2  
ACC Decision No. 71445  
Filed: January 25, 2010  
Effective: For all service rendered on  
and after January 1, 2010

**PRIVATE FIRE SERVICE**

**Availability**

Available for fire protection only and shall serve only a single property within the Company's service area and where facilities of adequate capacity and pressure are adjacent to the premises being served.

**PRIVATE FIRE SERVICE (Minimum Monthly Charge):**

4" Fire Line Service	\$25.00
6" Fire Line Service	35.00
8" Fire Line Service	45.00

**Terms and Conditions**

1. The customer will pay, without refund, the entire cost of the private fire service. Company's review and approval of the private fire service is limited only to the portion to be constructed in the ROW or easement.
2. The minimum diameter for private fire service will be four (4) inches. The maximum diameter shall not be larger than the diameter of the water main to which the fire protection service is attached.
3. If a water main of adequate size is not available adjacent to the premises to be served, then a new main from the nearest existing main of adequate size will be installed at the customer's expense.
4. All private fire services shall have a backflow prevention device approved by the Company and are subject to the Company's Cross-Connection Tariff. All backflow devices shall be installed as close as possible to the service connection and may be located within the customer's property or within the public right-of-way or easement. Where located within the customer's property, the Company and its duly authorized agents shall have the right of ingress to and egress from the property for all purposes related to said facilities.

APPROVED FOR FILING  
DECISION #: 71445

SUNRISE WATER CO.  
9098 W. Pinnacle Peak Rd.  
Peoria, Arizona 85383  
Filed by: J D. Campbell  
Title: President

**ORIGINAL**

Tariff Sheet No. 2A

ACC Decision No. 71445  
Filed: December 30, 2009  
Effective: For all service rendered on  
and after January 1, 2010

---

**PRIVATE FIRE SERVICE**

5. The customer must notify the Company in writing within 48 hours of private fire service system activation that results in the use of water in any amount.
6. No structure shall be built over the private fire service and the customer shall maintain and safeguard the area occupied by the service from traffic and other hazardous conditions. The customer will be responsible for any damage to the private fire service facilities whether resulting from use or operation of facilities on customer's premises or otherwise.
7. The customer's installation must be such as to separate effectively the private fire service from that of the customer's regular domestic water service. Any unauthorized use of water through the private fire service will be charged for at the applicable tariff rates and may be grounds for the Company's discontinuing private fire service without liability.
8. The customer acknowledges that the Company is not in the fire service business and is providing the services described in this Tariff strictly as an accommodation for the customer. **THE COMPANY MAKES NO WARRANTY, EXPRESSED OR IMPLIED, THAT ADEQUATE WATER OR WATER PRESSURE WILL BE AVAILABLE FOR FIRE SERVICE AT ANY TIME.** The Company will supply only such water at such pressures as may be available from its water system under normal operating conditions. The Company does not guarantee a specific water pressure or gallons-per-minute flow rate at any of the private fire service facilities installed. In the event service is interrupted or irregular or defective or fails from causes beyond the Company's control or through ordinary negligence of its employees, servants or agents, the Company will not be liable for any injuries or damages arising therefrom.
9. The customer shall make no claim against the Company for any loss or damage resulting from services provided under this schedule.

APPROVED FOR FILING  
DECISION #: 71445

# ORIGINAL

SUNRISE WATER CO.  
9098 W. Pinnacle Peak Rd.  
Peoria, Arizona 85383  
Filed by: J D. Campbell  
Title: President

Tariff Sheet No. 3  
ACC Decision No. 71445  
Filed: January 25, 2010  
Effective: For all service rendered on  
and after January 1, 2010

## SERVICE CHARGES

### Availability

In all cities, towns and unincorporated areas in which the Company provides general water utility services.

### Service Charges:

Establishment:	\$25.00
Establishment (After Hours)	35.00
Reconnection (Delinquent)	15.00
Reconnection (Delinquent, After Hours)	25.00
Meter Test (If Correct)	25.00
Deposit Requirement:	*
Residential Customer	
Deposit Requirement:	*
Non-Residential Customer	
Deposit Interest	6.00%
Re-establishment within 12 Months	**
NSF Check	\$35.00
Meter Reread	10.00
Deferred Payment, Per Month	1.50%
Late Payment Charge, Per Month	1.50%
Moving Customer Meter	***Cost

\* Per Commission Rule A.A.C. R14-2-403(B)

\*\* Months off system times the monthly minimum per Commission Rule A.A.C. R14-2-403 (D)

\*\*\* All items billed at cost shall include labor, materials and parts and all applicable taxes.

APPROVED FOR FILING  
DECISION #: 71445

**ORIGINAL**

SUNRISE WATER CO.  
9098 W. Pinnacle Peak Rd.  
Peoria, Arizona 85383  
Filed by: J D. Campbell  
Title: President

Tariff Sheet No. 4  
ACC Decision No. 71445  
Filed: January 25, 2010  
Effective: For all service rendered on  
and after January 1, 2010

**SERVICE LINE AND METER INSTALLATION CHARGES:**  
(Refundable pursuant to A.A.C. R14-2-405)

**Availability**

In all cities, towns and unincorporated areas in which the Company provides general water utility services.

	<u>Service Line Charge</u>	<u>Meter Charge</u>	<u>Total Charge</u>
3/4" Meter	\$445.00	\$ 255.00	\$ 700.00
1" Meter	495.00	315.00	810.00
1 1/2" Meter	550.00	525.00	1,075.00
2" Meter Turbo	830.00	1,045.00	1,875.00
2" Meter Compound	830.00	1,890.00	2,720.00
3" Meter & Above	Cost	Cost	Cost

APPROVED FOR FILING  
DECISION #: 71445



SUNRISE WATER CO.  
9098 W. Pinnacle Peak Rd.  
Peoria, Arizona 85383  
Filed by: J D. Campbell  
Title: President

Page 1 of 2

ACC No.  
Canceling ACC No. 58724  
Filed: June 30, 2010  
Effective: July 31, 2010

ORIGINAL

## CROSS-CONNECTION OR BACKFLOW TARIFF

### PURPOSE:

The purpose of this tariff is to protect Sunrise Water Co. ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

### REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

ADMINISTRATIVELY  
APPROVED FOR FILING

SUNRISE WATER CO.  
9098 W. Pinnacle Peak Rd.  
Peoria, Arizona 85383  
Filed by: J D. Campbell  
Title: President

Page 2 of 2

ORIGINAL

ACC No.  
Canceling ACC No. 58724

Filed: June 30, 2010

Effective: July 31, 2010

## CROSS-CONNECTION OR BACKFLOW TARIFF

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
  - a. assembly identification number and description;
  - b. location
  - c. date(s) of test(s);
  - d. description of repairs and recommendations for repairs made by tester;  
and
  - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

ADMINISTRATIVELY  
APPROVED FOR FILING